




System Operations Report


Stephanie Schwarz
Manager, Markets Coordination
Operating Committee
January 12th, 2022




Average Load Forecast Error



Daily Peak Forecast Error (December)







PJM's BAAL performance has exceeded the goal of 99% for each month in 2022.


- Five Spinning Events
- Eight Shared Reserve Event
- The following Emergency Procedures occurred:
 - 2 Maximum Generation Emergency Alerts
 - 5 Emergency Load Management Reduction Actions
 - 2 Maximum Generation Emergency Actions
 - 3 Cold Weather Alerts
 - 2 NERC EEA Level 1
 - 5 NERC EEA Level 2
 - 53 Post-Contingency Local Load Relief Warnings (PCLLRW)

- 185 Shortage Cases Approved
- The approved Shortage Cases occurred on:
 - 12/23/2022:
 - 58 Shortage Cases for intervals between 16:35 – 22:15
 - Factors: Load came in much higher than forecast and generation tripping or FTS
 - 12/24/2022:
 - 125 Shortage Cases for intervals between 00:20 – 00:40, 00:55, 01:59 – 12:20
 - Factors: Load came in much higher than forecast and generation tripping or FTS
 - 12/25/2022:
 - 1 Shortage Case for 04:40 interval
 - Due to load increase
 - 12/26/2022:
 - 1 Shortage Case for 00:20 interval
 - Due to low ACE



The 13-month average forced outage rate is 4.89% or 9,795 MW.
 The 13-month average total outage rate is 16.12% or 32,363 MW.

2021-2022 Planned Emergency, Unplanned, and Total Outages by Ticket



Note: "Unplanned Outages" include tripped facilities. One tripping event may involve multiple facilities.

PCLLRW Count Vs. Peak Load – Daily Values For 3 Months



Event	Date	Start Time	End Time	Duration	Region	Assigned (MW)	Response (MW)	Penalty (MW)
1	12/23/22	10:14:04	10:25:11	00:11:07	RTO	1791.4	948.9	842.5
2	12/23/22	16:17:51	18:09:20	01:51:29	RTO	1845.6	812.3	1033.3
3	12/24/22	00:05:01	00:30:44	00:25:43	RTO	1766.5	329.9	1436.6
4	12/24/22	02:23:38	02:54:13	00:30:35	RTO	1664.8	534.7	1130.1
5	12/24/22	04:23:41	05:51:13	01:27:32	RTO	1097.0	258.6	838.4

*Response is equal to Assigned for events with duration less than ten minutes

Presenter:
Stephanie Schwarz,
Stephanie.Schwarz@pjm.com

SME:
Ross Kelly,
Ross.Kelly@pjm.com

System Operations Report



Member Hotline

(610) 666 – 8980



(866) 400 – 8980

custsvc@pjm.com

Appendix


Goal Measurement: Balancing Authority ACE Limit (BAAL)

- The purpose of the new BAAL standard is to maintain interconnection frequency within a predefined frequency profile under all conditions (normal and abnormal), to prevent frequency-related instability, unplanned tripping of load or generation, or uncontrolled separation or cascading outages that adversely impact the reliability of the interconnection. NERC requires each balancing authority demonstrate real-time monitoring of ACE and interconnection frequency against associated limits and shall balance its resources and demands in real time so that its Reporting ACE does not exceed the BAAL ($BAAL_{LOW}$ or $BAAL_{HIGH}$) for a continuous time period greater than 30 minutes for each event.
- PJM directly measures the total number of BAAL excursions in minutes compared to the total number of minutes within a month. PJM has set a target value for this performance goal at 99% on a daily and monthly basis. In addition, current NERC rules limit the recovery period to no more than 30 minutes for a single event.



The 13-month average forced outage rate is 4.89% or 9,795 MW.
 The 13-month average total outage rate is 16.12% or 32,363 MW.

PCLLRW Count Vs. Peak Load – Daily Values For 13 Months



**PROTECT THE
POWER GRID
THINK BEFORE
YOU CLICK!**



Be alert to
malicious
phishing emails.

Report suspicious email activity to PJM.
(610) 666-2244 / it_ops_ctr_shift@pjm.com

