

Subregional RTEP Committee – Western FirstEnergy Supplemental Projects

July 8, 2022


Need Number: ATSI-2021-018
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 3/18/2022
Previously Presented: Need Meeting 07/16/2021
 Solutions Meeting – 08/16/2021

Supplemental Project Driver(s):
Customer Service

Specific Assumption Reference(s)
 Customer connection request evaluated per FirstEnergy’s “Requirements for Transmission Connected Facilities” document and “Transmission Planning Criteria” document.

Problem Statement
 New Customer Connection – A customer requested 69 kV transmission service for approximately 4 MVA of total load near the Cedar St – Frisco #1 69 kV Line.

Requested In-Service Date: May 1, 2022



Continued on next page...

Need Number: ATSI-2021-018
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 3/18/2022

Proposed Solution:

- Tap the Cedar St – Frisco #1 69 kV Line between Cedar St and Inmetco
- Install two network 69 kV disconnect switches
- Install one 69 kV tap switch
- Construct ~1 span of 69 kV into new substation
- Adjust relaying at Cedar St and Frisco substations

Alternatives Considered:


- Tap the Cedar St – Frisco #2 69 kV Line

Estimated Project Cost: \$1.4M

Projected In-Service: 05/01/2022

Supplemental Project ID: s2647

Model: 2020 RTEP model for 2025 Summer (50/50)



Need Number: ATSI-2021-017

Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 3/18/2022

Previously Presented: Need Meeting – 07/16/2021
Solution Meeting – 08/16/2021

Supplemental Project Driver(s):
Customer Service


Specific Assumption Reference(s)

Customer connection request evaluated per FirstEnergy’s “Requirements for Transmission Connected Facilities” document and “Transmission Planning Criteria” document.

Problem Statement

New Customer Connection – A customer requested 138 kV transmission service for approximately 23 MVA of total load near the London-Tangy 138 kV Line.

Requested In-Service Date: April 30, 2022



Continued on next page...

Need Number: ATSI-2021-017
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 3/18/2022

Proposed Solution:


Mitchell Delivery Point 138 kV Transmission Line Tap

- Construct a 138 kV tap (approximately 1-2 spans) off the London-Tangy 138 kV Line. Tap location is approximately 15 miles from the Tangy Substation.
- Add two SCADA control switches at transmission line tap location and one tap switch
- Adjust relay settings at London and Tangy substations

Alternatives Considered:

- No alternatives considered for this project

Estimated Project Cost: \$1.4 M
Projected In-Service: 4/30/2022
Supplemental Project ID: s2648
Model: 2020 Series 2025 Summer RTEP 50/50



Need Number: ATSI-2021-014
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 3/18/2022
Previously Presented: Need Meeting – 06/15/2021
 Solution Meeting – 08/16/2021


Supplemental Project Driver(s):
 Customer Service

Specific Assumption Reference(s)

Modification of existing customer connection request evaluated per FirstEnergy’s “Requirements for Transmission Connected Facilities” document and “Transmission Planning Criteria” document

Problem Statement

- The B-phase of existing 138-36 kV Lloyd transformer #2 has failed.



Continued on next page...

Need Number: ATSI-2021-014
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 3/18/2022

Proposed Solution:

Move Existing 138-36 kV Transformer

- Move the existing #3 transformer from Nathan Substation to the open bay position at Lloyd Substation in order to feed the distribution load. Retire the failed #2 Lloyd transformer in place.


Transformer Ratings:

- Failed #2 Lloyd Transformer**
 - 55 MVA SN / 66 MVA SE
- Existing #3 Nathan Transformer**
 - 72 MVA SN / 81 MVA SE

Alternatives Considered:

- New transformer installation at Lloyd Substation

Estimated Project Cost: \$0.0
Projected In-Service: 12/31/2021
Supplemental Project ID: s2649
Model: 2019 Series 2024 Summer RTEP 50/50



Need Number: ATSI-2019-073
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 3/18/2022
Previously Presented: Need Meeting – 11/22/2019
 Solution Meeting – 03/19/2020
 Re-Present Solution Meeting – 08/16/2021

Project Driver:
Equipment Material Condition, Performance and Risk

Specific Assumption References:

Global Factors

- System reliability and performance
- Substation / line equipment limits


Upgrade Relay Schemes

- Relay schemes that have a history of misoperation
- Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
- Communication technology upgrades
- Bus protection schemes

Problem Statement:

- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform adequately during a fault
- In many cases the protection equipment cannot be repaired due to a lack of replacement parts and available expertise in the outdated technology.
- Transmission line ratings are limited by terminal equipment.

Continued on next page...



...Continued from previous page

ATSI-2019	Transmission Line / Substation Locations	Existing Line/Terminal Equipment MVA Rating (SN / SE)	Existing Conductor/Transformer MVA Rating (SN / SE)	Limiting Terminal Equipment
-073	Eastlake-Lloyd 138 kV Q12 Line 1. Eastlake – Liberty 2. Lamont – Lloyd	1. 273 / 287 2. 103 / 132	1. 273 / 332 2. 148 / 151	Substation Conductor, Relay, CTs @ Lloyd

Continued on next page...

...Continued from previous page

ATSI-2019	Transmission Line / Substation Locations	New MVA Line Rating (SN / SE)	Proposed Solution	Estimated Costs (\$ M)	Target ISD
-073 (s2228)	Eastlake-Lloyd 138 kV Q12 Line 1. Eastlake – Liberty 2. Lamont – Lloyd	1. 273 / 332 2. 147 (WN) / 164 (WE)	At Eastlake replace the Q-12 circuit breaker, line disconnect switch, relaying, line terminal arresters, and line CVTs. At Lloyd remove the Q12 line relaying due to Lloyd TR#2 moving to the Q11 bay position.	1.1	03/03/2023

Supplemental Project ID: s2228

Need Number: ATSI-2021-012

Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 7/8/2022

Previously Presented: Need Meeting – 05/21/2021
Solutions Meeting – 11/19/2021

Supplemental Project Driver(s):
Customer Service


Specific Assumption Reference(s)

Customer connection requests will be evaluated per FirstEnergy’s “Requirements for Transmission Connected Facilities” document and “Transmission Planning Criteria” document.

Problem Statement

New Customer Connection – Penn Power Distribution has requested a new 69 kV delivery point near the Maple – Pine 69 kV Line due to a thermal overload identified on the Mars #2 69-12.47 kV transformer. The anticipated load of the new customer connection is 8.7 MVA.

Requested In-Service Date: 06/01/2022



Need Number: ATSI-2021-012

Process Stage: Solutions Meeting – 11/19/2021

Previously Presented: Need Meeting – 05/21/2021

Proposed Solution:

- Tap the Maple – Pine Y-192 69 kV line between Callery and Concast Metals
- Install one network 69 kV disconnect switch with SCADA
- Construct ~1 span of 69 kV into new substation

Alternatives Considered:


- No alternatives were considered

Estimated Project Cost: \$0.8M

Projected In-Service: 06/30/2022

Supplemental Project ID: s2804

Model: 2020 RTEP model for 2025 Summer



Need Number: ATSI-2021-025 and ATSI-2021-026
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 7/8/2022
Previously Presented: Need Meeting - 10/15/2021
 Solution Meeting – 02/18/2022

Project Driver:
Equipment Material Condition, Performance and Risk

Specific Assumption References:

Global Factors

- System reliability and performance
- Substation / line equipment limits


Upgrade Relay Schemes

- Relay schemes that have a history of misoperation
- Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
- Communication technology upgrades
- Bus protection schemes

Problem Statement:

- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform adequately during a fault
- In many cases the protection equipment cannot be repaired due to a lack of replacement parts and available expertise in the outdated technology.
- Transmission line ratings are limited by terminal equipment.

Continued on next page...



...Continued from previous page

Need Number	Transmission Line / Substation Locations	Existing Line / Terminal Equipment MVA Rating (SN / SE)	Existing Conductor / Transformer MVA Rating (SN / SE)	Limiting Terminal Equipment
ATSI-2021-025	Jackman-Westgate 138 kV	278 / 343 327 (WN) / 396 (WE)	278 / 343 327 (WN) / 420 (WE)	Substation Conductor
ATSI-2021-026	Lemoyne-Troy 345 kV 1. Lemoyne terminal	1,146 / 1,208 1,309 (WN) / 1,352 (WE)	1,542 / 1,878 1,746 (WN) / 2,225 (WE)	CTs, Circuit breaker B1, Substation Conductor, and disconnect switches

Selected Solution:

Need Number	Transmission Line / Substation Locations	New MVA Line Rating (SN / SE)	Scope of Work	Supplemental Project ID	Estimated Cost (\$ M)	Target ISD
ATSI-2021-025	Jackman-Westgate 138 kV	278 / 343 327 (WN) / 420 (WE)	<ul style="list-style-type: none"> • Replace Jackman-Westgate line relaying with primary and backup line relays • Replace 138 kV breakers at Westgate and Jackman substations with associated disconnect switches • Replace line traps, CCVTs • Replace substation conductor to exceed transmission line ratings 	s2697	\$2.5	4/1/2022
ATSI-2021-026	Lemoine-Troy 345 kV 1. Lemoine terminal	1,542 / 1,878 1,746 (WN) / 2,225 (WE)	<ul style="list-style-type: none"> • Replace 2000 A breaker with 3000 A • Replace live parts of disconnect switches to increase amperage rating to 3000 A • Replace substation conductor to exceed transmission line ratings 	s2698	\$1.8	3/30/2022

Model: 2020 RTEP model for 2025 Summer (50/50)

Need Number: ATSI-2021-019

Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 10/11/2022

Previously Presented: Re-Present Solution Meeting – 03/18/2022
Solution Meeting – 08/16/2021
Need Meeting – 07/16/2021

Supplemental Project Driver(s):
Customer Service


Specific Assumption Reference(s)

Customer connection request evaluated per FirstEnergy’s “Requirements for Transmission Connected Facilities” document and “Transmission Planning Criteria” document.

Problem Statement

New Customer Connection – A customer requested 138 kV transmission service for approximately 20 MVA of total load near the Delta – Wauseon 138 kV line.

Requested In-Service Dates: 10 MVA by November 1, 2021
10 MVA increase by November 1, 2026





ATSI Transmission Zone M-3 Process Delta – Wauseon 138 kV New Customer

Need Number: ATSI-2021-019
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan - 10/11/2022


Selected Solution:
New 138 kV Customer

- Construct a 138 kV tap off the Delta – Wauseon 138 kV line to the customer substation. The customer substation tap location is approximately a 0.9 mile extension from the existing structures to the new customer substation.
- Add MOAB and SCADA to two new switches on the Delta – Wauseon 138 kV line.
- Upgrade 336 ACSR TL Drop at Lemoyne Substation (Dowling Line Exit)

Line Ratings:

Delta-Wauseon 138 kV Line: No ratings change
 Dowling-Lemoyne 138 kV Line:
 Before proposed project: 160/192 MVA SN/SE
 After proposed project: 252/291 MVA SN/SE

Estimated Project Cost: \$2.1M
Projected In-Service: 06/01/2022
Supplemental Project ID: s2696
Model: 2020 Series 2025 Summer RTEP 50/50



Need Number: ATSI-2019-011

Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 10/11/2022

Previously Presented: Re-Present Solutions Meeting – 07/22/2022
Needs Meeting 01/14/2019
Solutions Meeting 03/25/2019

Project Driver(s):
Equipment Material, Condition, Performance and Risk
Operational Flexibility and Efficiency
Infrastructure Resilience

Specific Assumption Reference(s)

Global Considerations

- System reliability and performance
- Substation / Line equipment limits


Upgrade Relay Schemes

- Bus protection schemes
- Relay schemes that have a history of mis-operation

Problem Statement

Evergreen Substation 138 kV Equipment and Protection

- BES bus protection is presently performed by a complex scheme that has a history of causing mis-operations at other substations. The scheme uses distributed electromechanical relays to exclude a bus fault rather than detecting the bus fault directly.



Need Number: ATSI-2019-011
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan - 10/11/2022

Selected Solution:


Evergreen 138 kV Relay Upgrades

- Replace bus protection scheme with dual differential protection.
- Replace bus PTs due to condition
- Replace 3 breakers (B23, B24, and B27 bus transfer) due to condition and insufficient lack of sufficient CTs for proper system to support standard, redundant bus protection
- Add a new 138 kV bus tie breaker, disconnect switches, and relaying to eliminate exposure of the transmission system related to customer-owned equipment failures/faults in the substation

Transmission Line Ratings:

- Evergreen-Ivanhoe 138 kV Line
 - Before Proposed Solution: 226 MVA WN / 249 MVA WE
 - After Proposed Solution: 226 MVA WN / 286 MVA WE
- Evergreen-Niles 138 kV Line
 - Before Proposed Solution: 224 MVA SN / 293 MVA SE
 - After Proposed Solution: 278 MVA SN / 339 MVA SE

Estimated Project Cost: \$4.2M
Projected IS Date: 12/08/2023
Supplemental Project ID: s1954



Need Number: ATSI-2021-027
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 10/11/2022
Previously Presented: Need Meeting – 11/30/2021
 Solution Meeting – 07/12/2022

Supplemental Project Driver(s):
Operational Flexibility and Efficiency
Infrastructure Resilience


Specific Assumption Reference(s)

- System Reliability and Performance
- Load at risk in planning and operational scenarios
- Load and/or customers at risk on single transmission lines

Add/Expand Bus Configuration

- Loss of substation bus adversely affects transmission system performance
- Reduce amount of exposed potential local load loss during contingency conditions.
- Accommodate future transmission facilities

Continued on next page...





Need Number: ATSI-2021-027
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan - 10/11/2022

Selected Solution:


- Install two 345 kV circuit breakers at Melbourne 345 kV Substation
- Install two 345-138 kV transformers
- Construct a four breaker (future 6) 138 kV ring bus at Melbourne Substation
- Loop in the Delta-Wauseon 138 kV line into Melbourne 138 kV Substation
- Install two 138 kV line switches, one near Lear tap and one near Worthington tap
- Install one 138 kV circuit breaker at Delta 138 kV Substation

Line Ratings:

Wauseon-Melbourne 138 kV Line:
 After proposed project: 278/343 MVA SN/SE
 Delta-Melbourne 138 kV Line:
 After proposed project: 278/343 MVA SN/SE

Estimated Project Cost: \$25.1M
Projected In-Service: 12/01/2025
Supplemental Project ID: s2756
Model: 2021 Series 2026 Summer RTEP 50/50

ATSI Transmission Zone M-3 Process Delta/Wauseon Area



Legend	
500 kV	
345 kV	
138 kV	
69 kV	
34.5 kV	
23 kV	
New	

Need Number: ATSI-2022-002
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 10/11/2022
Previously Presented: Need Meeting – 03/18/2022
 Solution Meeting – 07/22/2022

Supplemental Project Driver(s):
 Customer Service


Specific Assumption Reference(s)

Customer connection request evaluated per FirstEnergy’s “Requirements for Transmission Connected Facilities” document and “Transmission Planning Criteria” document.

Problem Statement

New Customer Connection – A customer requested 69 kV transmission service for approximately 15 MVA of total load near the Carbon Limestone (Lowellville) 69 kV line.

Requested In-Service Date: December 30, 2022




ATSI Transmission Zone M-3 Process Lowellville-Carbon Limestone 69 kV New Customer- Solution

Need Number: ATSI-2022-002
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan - 10/11/2022

Selected Solution:
69 kV Transmission Line Tap

- Install one SCADA controlled transmission line switch
- Adjust relay settings at Lowellville substation

Estimated Project Cost: \$0.1M
Projected In-Service: 09/02/2022
Supplemental Project ID: s2757



Need Number: ATSI-2021-003
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 10/11/2022
Previously Presented: Need Meeting – 01/15/2021
 Solution Meeting – 07/22/2022

Supplemental Project Driver(s):
 Customer Service


Specific Assumption Reference(s)

Customer connection requests will be evaluated per FirstEnergy’s “Requirements for Transmission Connected Facilities” document and “Transmission Planning Criteria” document.

Problem Statement

New Customer Connection – A customer requested 69 kV transmission service for approximately 5.6 MVA of total load near the East Archbold – Stryker 69 kV line.

Requested In-Service Date: May 1, 2021




Need Number: ATSI-2021-003
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan - 10/11/2022

Selected Solution:
New 69 kV Customer

- Construct a 69 kV tap (approximately 0.1 miles) off the East Archbold – Stryker 69 kV line to the customer substation. The customer substation tap location is approximately 6 miles from Stryker substation.
- Add two SCADA control switches at transmission line tap location and one tap switch
- Revise relay settings at East Archbold and Stryker Substations

Estimated Project Cost: \$1.7M
Projected In-Service: 12/01/2022
Supplemental Project ID: s2758
Model: 2019 Series 2024 Summer RTEP 50/50



Need Number: ATSI-2021-015
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 10/11/2022
Previously Presented: Need Meeting – 08/16/2021
 Solution Meeting – 07/22/2022

Supplemental Project Driver(s):
*Equipment Material Condition, Performance, and Risk
 Infrastructure Resilience*

Specific Assumption Reference(s):

Global Factors


- System Reliability and Performance
- Load at risk in planning and operational scenarios
- Increase line loading limits
- Age/condition of transmission line conductors

Line Condition Rebuild/Replacement

- Transmission lines with loading at 80% or greater
- End of Life Methodology

Problem Statement


- The Leroy Center – Mayfield Q2 138 kV line loads to 95% under contingency conditions in the 2020 RTEP Case.
- The Leroy Center – Mayfield Q2 138 kV line has the potential to feed 7,017 customers and 20 MW at the Pawnee Substation, back up feed to LC-MF Q1 138 kV line.



Need Number: ATSI-2021-015
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan - 10/11/2022

Problem Statement Continued...

- The existing conductor is 4/0 CU and can cause protection issues due to not being able to handle the short circuit current for faults.
- Age/condition of transmission line conductors and hardware (mid 1940s).
- The Leroy Center – Mayfield Q2 138 kV line has experienced one (1) sustained outage in the past five years.



Need Number: ATSI-2021-015
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan - 10/11/2022


Selected Solution:

- Reconductor the Leroy Center-Mayfield Q2 138 kV Line (~16 miles) from Leroy Center - Pawnee Tap and Pawnee Tap - Mayfield with 336 ACSS. Replace tower structures, insulators and hardware as needed to address condition items and support new conductor.

Transmission Line Ratings:

- Leroy Center - Mayfield Q2 138 kV Line
 - Before Proposed Solution: 115 MVA SN/ 115 MVA SE
 - After Proposed Solution: 252 MVA SN / 291 MVA SE

Estimated Project Cost: \$14.9M
Projected In-Service: 06/01/2026
Supplemental Project ID: s2759
Model: 2020 Series 2025 Summer RTEP 50/50



Need Number: AMPT-2021-005

Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan – 10/11/2022

Previously Presented: Need Meeting – 11/19/2021
Solution Meeting – 2/18/2022

Supplemental Project Driver(s): Customer Service


Specific Document

Problem Statement:

AMPT's Amherst Tap is an approximately 1.85 mile segment of a 2.85 mile radial tap supplied from ATSI's Henrietta-Johnson 69 kV line. Two stations are served off the Tap – Woodings and Cannon.

The City of Amherst has requested a 2nd supply to support the load (approximately 28 MVA). The radial supply presents a single point of failure that jeopardizes reliability for the City.

AMPT's Transmission Facilities Interconnection Requirements specify looped facilities for loads exceeding 5 MVA or 35 MW-mile thresholds.



Need Number: AMPT-2021-005
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan - 10/11/2022

Selected Solution:

AMPT Identified Scope

- Construct a greenfield 138 kV double circuit line for approximately 0.4 miles using 954 54/7 kcmil ACSS conductor and tap into the existing Beaver-Black River (ATSI) 138 kV line.
- At Woodings (Amherst Sub #2) 69/12 kV Substation - Expand the sub with the installation of three (3) 138 kV circuit breakers; Install one (1) 138/69/12kV 130 MVA transformer; upgrade the 69 kV bus to 2000A, install two (2) 69 kV circuit breakers
- At Cannon (Sub #1) 69/12 kV Substation - Install one (1) 69 kV breaker towards Nordson; Replace 600A bus disconnect switch with one rated at 1200A

ATSI Identified Scope (\$2.8 M)

- Design and construct tap structure(s) at tap location
- Upgrade line relaying with new panel at Black River
- Upgrade line relaying with new panel at Beaver
- Install/complete fiber connection to Beaver and Black River substations
- Provide/install four (4) 69 kV revenue metering equipment packages at Amherst Muni substations






ATSI Transmission Zone M3 Process Amherst, OH

Need Number: AMPT-2021-005
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan - 10/11/2022

Selected Solution (Continued):

Total Estimated ATSI Transmission Cost: \$2.8 M
Projected In-Service: 12/31/2023
Supplemental Project ID: s2671.1





Legend	
500 kV	
345 kV	
138 kV	
69 kV	
34.5 kV	
23 kV	
New	



ATSI Transmission Zone M3 Process Rye Beach Road, Greenfield – Shinrock 69 kV line

Need Number: AMPT-2021-001
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan - 10/11/2022
Previously Presented: Solution Meeting – 6/15/2022
Need Meeting – 5/21/2021

Supplemental Project Driver(s): Customer Service

Specific Assumption Reference(s): AMPT Transmission Facilities Interconnection Requirements Document

Problem Statement:

Rye Beach Road 69kV Substation (AMP Transmission)

The existing interconnection is a 0.15 mile single radial tap from the ATSI Greenfield-Shinrock 69kV line to the Rye Beach Road (Huron Muni) substation.

Current peak load at Rye Beach Road is 26 MW, projected to increase to 38 MW by 10/1/21 and 40 MW by 10/1/22.

Also, AMPT Interconnection requirements specify a need for a second source for loads 5 MVA and above.





ATSI Transmission Zone M3 Process

Rye Beach Road, Greenfield – Shinrock 69 kV line

Need Number: AMPT-2021-001

Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan - 10/11/2022

Selected Solution:

AMPT Identified Scope

- At Rye Beach Road (Huron Muni) 69/12 kV Substation - Expand the current 69 kV station to a 4-CB ring bus arrangement to accommodate a 2nd 69 kV circuit (toward Shinrock). Build the new 69 kV ring bus to 2000A ratings; Install four (4) 69 kV circuit breakers; Install one (1) 69 kV circuit switcher; install ten (10) 69 kV bus disconnect switches (2000A);
- Relocate existing FE revenue metering at the substation as a result of the system reconfiguration.

FE Identified Scope (\$2.8 M)

- Build approximately 0.2 miles 69 kV line into AMPT's Rye Beach Road substation in a separate right of way using 556 kcmil ACSR conductor.
- Loop in/out the Greenfield-Shinrock 69 kV line into AMPT's Rye Beach Road Substation.
- FE will install two dead-end structures just outside of the AMPT's substation, for the new and existing line, this structure will be the point of interconnection (POI).
- The FE facilities/lines will terminate at the dead-end structure.
- FE will install two 1200 A motor-operated switches on the new and existing line at the dead-end structures.
- Adjust relay settings at Shinrock Substation
- Replace existing Greenfield (Shinrock Line) relay with a standard line relaying panel





ATSI Transmission Zone M3 Process

Rye Beach Road, Greenfield – Shinrock 69 kV line

Selected Solution (Continued):

Total ATSI Estimated Transmission Cost: \$2.8 M


Projected In-Service: 06/01/2025

Project Status: Scoping (AMPT) Conceptual (FE)


Supplemental Project ID: s2749.2



Existing



Proposed



Legend	
500 kV	
345 kV	
138 kV	
69 kV	
34.5 kV	
23 kV	
New	

Need Number: AMPT-2022-001

Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan


Previously Presented: Need Meeting – 1/21/2022
Solution Meeting – 6/15/2022

Supplemental Project Driver(s): Customer Service

Specific Assumption Reference(s): AMPT Transmission Facilities Interconnection Requirements Document

Problem Statement:

New Customer Connection - The Village of Pioneer has requested a new 69 kV service point near the AMPT tap off ATSI's East Fayette-Exit 2 69 kV line. This request was made to support a new retail customer with an anticipated load of approximately 16 MVA..





ATSI Transmission Zone M3 Process Pioneer, OH


Need Number: AMPT-2022-001
Process Stage: Submission of Supplemental Project for Inclusion in the Local Plan

Selected Solution:

FE Identified Scope (\$0.25M)

- Provide two (2) 69 kV revenue metering equipment packages for the new Kexon Delivery Point.
- Revise relay settings at East Fayette and Snyder substations.

Total ATSI Estimated Transmission Cost: \$0.25 M
Projected In-Service: 10/31/2023
Project Status: Engineering
Supplemental Project ID: s2806.1



Revision History

3/18/2022 – V1 – Original version posted to pjm.com (s2647, s2648, s2649 & s2228)

7/8/2022 – V2 – Addition of s2696, s2697 & s2698.

10/11/2022 – V3 – Addition of s2696, s1954, s2756, s2757. s2758, s2759, s2671.1 & s2749.2

10/26/2022 – V4 – Correction of ATSI-2021-012 supplemental ID from s2696 to s2804

12/01/2022 – V5 – Addition of AMPT project AMPT-2022-001 (s2806.1)