



Market Efficiency Update

Transmission Expansion Advisory Committee
November 8, 2018

2018/19 Long Term Window

- Problem Statement and Eligible Congestion Drivers posted on the Competitive Planning Process web page
 - <https://www.pjm.com/planning/competitive-planning-process.aspx>
- Modeling data and supporting documentation posted on the Market Efficiency web page
 - <http://www.pjm.com/planning/rtep-development/market-efficiency.aspx>
- Long Term Proposal window opened on November 2nd, 2018
- Long Term Proposal window will close on March 1st, 2019
- Window Related Questions
 - Window related questions should be posted to the PJM Planning Community:
<https://pjm.force.com/planning/s/>

- Market Efficiency Web Page located at
 - <http://www.pjm.com/planning/rtep-development/market-efficiency.aspx>
- Posted Market Efficiency Base Case (database date 11-01-2018)
 - Market Efficiency Base Case files for all study years (PROMOD 11.1.13 XML format)
 - Access requires CEII confirmation (PJM and MISO)
 - Access requires PROMOD vendor (ABB) confirmation
 - Posted model includes all years: 2019, 2023, 2026, 2029
- Additional PROMOD modeling files
 - PROMOD 15-years Monte Carlo outage library (.lib)
 - PROMOD Event file (.eve)
- Also posted separate PROMOD XML file to remove FSA units

- Auxiliary Files
 - Benefit/Cost Evaluation Tool
 - 2018 ARR Data
 - Benchmark test case and results
 - Procedure for executing PROMOD Simulations
- Assumptions and Simulation Results (Informational)
 - 2018 Market Efficiency Assumptions Whitepaper
 - Congestion results from posted base case (simulated years 2023 and 2026)

Sensitivity	Range
Load Sensitivity	Plus or Minus 2%
Gas Sensitivity	Plus or Minus 20% Henry Hub
No FSA Sensitivity	Remove all units with FSA or suspended ISA status

- PJM reserves right to add sensitivities as necessary.

Congestion Drivers

- Congestion results associated with the Long Term Window Base Case are posted on Market Efficiency web page:
 - <https://www.pjm.com/-/media/planning/rtep-dev/market-efficiency/private-econ-plan-process/2023-2026-preliminary-market-efficiency-base-case-congestion-results.ashx?la=en>
- This file includes congestion results for simulation years 2023 and 2026
- Also included are the congestion results for the noFSA sensitivity case.

- In determining eligible congestion drivers PJM considered
 - binding flowgates internal to the PJM footprint (including tie lines)
 - active Market-to-Market flowgates listed in the NERC book of flowgates
 - potential future Market-to-Market flowgates between PJM and MISO
- Eligible congestion drivers were selected to focus proposals on significant issues
- Only proposals which address one or more of these PJM identified congestion drivers will be evaluated
 - If the proposal does not substantially address a PJM identified congestion driver, or is otherwise substantially deficient or is seriously flawed, it will be rejected and the proposer will be notified

- **Hours Binding**
 - Annual simulated congestion frequency of at least 25 hours in each 2023 and 2026 study years
- **Congestion Threshold**
 - Lower voltage facilities: minimum of \$1 million congestion in each 2023 and 2026 study years
 - Regional facilities: minimum of \$10 million congestion in each 2023 and 2026 study years
 - Interregional facilities: minimum of \$0.5 million congestion in each 2023 and 2026 study years (lower threshold as there may be interregional benefits in addition to the regional benefits)

- PJM may not recommend proposals for certain facilities meeting the criteria due to following exceptions:
 - Congestion is significantly influenced by a FSA generator or a set of FSAs
 - Majority of the congestion was already addressed in previous window(s)
 - Simulated congestion for future study years displays a declining trend

Note: PJM reserves right to add other exceptions as necessary.



Simulated Market Congestion Results


Constraint	From Area	To Area	Base with FSAs (\$Million)		Sensitivity No FSAs (\$Million)		Base with FSAs (Hours Binding)		Comment
			2023 Simulated Year	2026 Simulated Year	2023 Simulated Year	2023 Simulated Year	2023 Simulated Year	2023 Simulated Year	
AP South Interface	-	-	\$75.04	\$96.73	\$12.67	\$9.28	1,226	1,363	Large congestion reduction without FSA generation. Significant portion of congestion addressed in previous windows.
North Waverly to E Sayre 115 kV	NYZC	PN	\$8.93	\$17.30	\$5.23	\$6.90	3,367	4,421	SPS exists. NY reviewing
Hunterstown to Lincoln 115 kV	ME	ME	\$7.45	\$10.56	\$24.99	\$34.82	865	1,010	Solicit
Cumberland TR2 to Juniata Bus 1 230 kV	PPL	PPL	\$8.99	\$13.10	\$0.73	\$4.10	357	316	Solicit
Bosserman to Trail Creek 138 kV	AEP	MISOE	\$7.04	\$9.79	\$0.69	\$0.78	265	340	Solicit
Face Rock to Face Rock-Five Forks 69 kV	PPL	PPL	\$4.55	\$3.48	\$1.01	\$0.66	166	120	Declining congestion
Monroe 1&2 to Wayne 345 kV	MISOE	MISOE	\$4.38	\$9.51	\$0.09	\$2.26	148	271	Solicit
He Hubbell to Sunman Weisburg 138 kV	MISOC	MISOC	\$3.19	\$3.20	\$0.42	\$0.80	122	110	Solicit
Dauphin TR1 to Copperstone/N Lebanon 230 kV	PPL	PPL	\$2.87	\$1.12	\$0.00	\$0.00	349	85	Congestion depends on one FSA unit.
Furnace Run to Conastone 230 kV	PECO	BGE	\$2.24	\$2.19	\$0.28	\$0.29	80	78	Large congestion reduction without FSA generation. Significant portion of congestion addressed in previous windows.
Towanda East to N. Meshoppen 115 kV	PN	PN	\$1.89	\$6.51	\$0.04	\$0.25	1,180	2,080	Large congestion reduction without FSA generation.
Milton to Montour 230 kV	PPL	PPL	\$0.97	\$0.34	\$0.01	\$0.00	234	82	Under \$1 million
Marblehead North Bus 1 161/138 kV	MISOC	MISOC	\$0.95	\$0.60	\$2.97	\$1.34	160	118	Solicit
50045005 Interface	-	-	\$0.80	\$19.97	\$0.02	\$3.57	92	756	Under \$1 million
Sullivan to Casey West East Bus 345 kV	AEP	MISOC	\$0.65	\$0.42	\$0.06	\$0.00	32	34	Under \$1 million
BC PEPCO Interface	-	-	\$0.63	\$0.59	\$0.00	\$0.00	25	22	Under \$1 million
Clifty Creek to Northside 138 kV	OVEC	LKE	\$0.58	\$2.59	\$0.00	\$0.05	23	90	Under \$1 million
E Frankfort to Goodings 345 kV	COMED	COMED	\$0.56	\$1.46	\$0.33	\$0.69	58	145	Solicit



Recommended Congestion Drivers


2018/19 RTEP Market Efficiency Window Eligible Congestion Drivers			ME Base Case with FSA units (Annual Congestion \$million)		ME Base Case with FSA units (Hours Binding)		Comment	Potential Upgrades
Constraint	FROM AREA	TO AREA	2023 Simulated Year	2026 Simulated Year	2023 Simulated Year	2026 Simulated Year		
Hunterstown to Lincoln 115 kV	METED	METED	\$ 7.45	\$ 10.56	865	1010	Internal Flowgate	
Monroe 1&2 to Wayne 345 kV	MISOE	MISOE	\$ 4.38	\$ 9.51	148	271	M2M	
He Hubbell to Sunman Weisburg 138 kV	MISOC	MISOC	\$ 3.19	\$ 3.20	122	110	M2M	
E Frankfort (R) to Goodings (R) 345 kV	COMED	COMED	\$ 0.56	\$ 1.46	58	145	M2M	
Cumberland TR2 to Juniata Bus 1 230 kV	PLGRP	PLGRP	\$ 8.99	\$ 13.10	357	316	Internal Flowgate	
Marblehead North Bus 1 138/161	MISOC	MISOC	\$ 0.95	\$ 0.60	160	118	M2M	A PJM/MISO TMEP has been proposed for this facility
Bosserman to Trail Creek 138 kV	AEP	MISOE	\$ 7.04	\$ 9.79	265	340	M2M	

- Area: METED
- Voltage: 115 kV
- Simulated Market Congestion
 - 2023 (\$mill): 7.45
 - 2026 (\$mill): 10.56




He Hubbell to Sunman Weisburg 138 kV

- Area: MISO
- Voltage: 138kV
- Simulated Market Congestion
 - 2023 (\$mill): 3.19
 - 2026 (\$mill): 3.20




E Frankfort (R) to Goodings (R) 345 kV

- Area: COMED
- Voltage: 345 kV
- Simulated Market Congestion
 - 2023 (\$mill): 0.56
 - 2026 (\$mill): 1.46




- Area: PLGRP
- Voltage: 230 kV
- Simulated Market Congestion
 - 2023 (\$mill): 8.99
 - 2026 (\$mill): 13.10




- Area: MISO
- Voltage: 138/161 kV
- Simulated Market Congestion
 - 2023 (\$mill): 0.95
 - 2026 (\$mill): 0.60

Note: A PJM/MISO TMEP has been proposed for this facility



- Area: AEP
- Voltage: 138 kV
- Simulated Market Congestion
 - 2023 (\$mill): 7.04
 - 2026 (\$mill): 9.79



Step	Timeline
Long Term Proposal Window	November 2018 - February 2019
2018 Reevaluation Analysis	November – December 2018
2018 Acceleration Analysis	November – December 2018
Analysis of Proposed Solutions	March - November 2019
Final TEAC Review and Board Approval	November - December 2019

2018 Reevaluation Approved Market Efficiency Projects

- Applies to market efficiency projects approved during the 2014/15 and 2016/17 RTEP Windows
- Using the Market Efficiency Base Case
- Projects already in-service, under construction or with a near in-service date will not be reevaluated
- Projects must meet the B/C criterion of 1.25
- Analysis Status
 - 9 projects already in service or under construction (see slide 17 for details)
 - 5 projects completed reevaluation and passed
 - 4 projects reevaluation in progress
- PJM anticipates completing the reevaluation process by the December 2018 TEAC meeting



Projects In Service or Under Construction

PJM Window Project ID	Baseline#	Type	Area	Constraint	Status	Last Updated Date	Description
201415_1-2B	b2691	Upgrade	ME/PPL	Brunner Island to Yorkana 230 kV	IS	11/06/2017	Reconductor three spans limiting Brunner Island - Yorkana 230 kV line, add 1 breaker to Brunner Island switchyard, upgrade associated terminal equipment
201415_1-4J	b2698	Upgrade	AEP	Jacksons Ferry to Cloverdale 765 KV	IS	10/31/2018	Replace relays at Cloverdale and Jackson's Ferry substations
201415_1-10B	b2693	Upgrade	COMED	Wayne to South Elgin 138 kV	IS	11/01/2018	Replace L7915 B phase line trap at Wayne substation
201415_1-10D	b2728	Upgrade	COMED	Loretto to Wilton 345 kV (RPM)	IS	05/21/2018	Mitigate sag limitations on Loretto - Wilton Center 345 kV Line and replace station conductor at Wilton Center
201415_1-12A	b2689.1-3	Upgrade	DUQ	Dravosburg to West Mifflin 138 kV	IS	1: 05/02/2018 2: 10/31/2018 3: 01/22/2018	Reconductor ~7 miles of the Woodville - Peters 138 kV circuit. Reconfigure West Mifflin-USS Clairton 138 kV circuit. Upgrade terminal equipment
201415_1-13E	b2695	Upgrade	DPL	Worcester to Ocean Pines (I) 69 kV	IS	04/04/2018	Rebuild Worcester - Ocean Pine 69 kV ckt. 1
201415_1-18G	b2688.1-3	Upgrade	APS	Taneytown to Carroll 138 kV	1: UC 2,3: IS	1: 09/25/2018 2: 06/07/2018 3: 06/07/2018	Upgrade terminal equipment on the Lincoln - Carroll 115/138kV path.
201415_1-2A	b2690	Upgrade	PPL/BGE	Safe Harbor to Graceton 230 kV	UC	10/17/2018	Reconductor two spans of the Graceton - Safe Harbor 230 kV transmission line
201415_1-18I	b2696	Upgrade	APS/ATSI	Krendale to Shanor Manor 138 kV	UC	10/31/2018	Upgrade 138 kV substation equipment at Butler, Shanor Manor and Krendale substations

IS – In Service
UC – Under Construction



Reevaluations Completed

PJM Window Project ID	Baseline#	Type	Area	Constraint	BC Reevaluation 2018	Capital Cost (\$ million)	Reevaluation TEAC Date	Status	Projected ISD	Description
201415_1-4I	b2697.1-2	Upgrade	AEP	Fieldale to Thornton 138 kV	3.30	\$0.75	11/8/2018	EP	1: 06/01/2019 2: 12/31/2019	Mitigate violations identified by sag study to operate Fieldale-Thornton-Franklin 138 kV overhead line conductor at its max. operating temperature Replace terminal equipment at Danville and East Danville substations
201415_1-9A*	b2743.1-8, b2752.1-7	Greenfield	APS/BGE	AP-South	1.40*	\$372.23	9/13/2018	EP	11/01/2020	New double-circuit Rice – Ringgold 230 kV. New double-circuit Furnace Run - Conastone 230 kV. Reconductor Conastone – NWest 230 kV.
201415_1-11H	b2694	Upgrade	PECO	Peach Bottom 500 kV	1.76	\$9.70	11/8/2018	EP	06/01/2019	Increase ratings of Peach Bottom 500/230 kV transformer
Optimal Caps	b2729	Upgrade	DOM	AP-South	2.51	\$8.98	11/8/2018	EP	12/01/2019	New capacitor banks at Brambleton, Ashburn, Shelhorn and Liberty substations
201617_1-5E	B2992.1-4	Upgrade	BGE	Conastone - Graceton - Bagley 230 kV	9.18	\$39.65	10/11/2018	EP	06/01/2021	Reconductor the Conastone to Graceton 230 kV 2323 & 2324 circuits Add Bundle conductor on the Graceton-Bagley-Raphael Road 2305 & 2313 230kV circuits Reconductor Raphael Road - Northeast 2315 & 2337 circuits

EP – Engineering Procurement

* 9A Ratio updated based on Transource cost update from October 2018



Reevaluation In Progress

PJM Window Project ID	Baseline#	Type	Area	Constraint	Status	Projected ISD	Description
201415_1-10J	b2692.1-2	Upgrade	COMED	Cordova to Nelson 345 kV	1: EP 2: UC	06/01/2019	Replace station equipment at Nelson, ESS H-471 and Quad Cities Upgrade conductor ratings of Cordova - Nelson, Quad Cities - ESS H-471 and ESS H-471 - Nelson 345 kV lines and mitigating sag limitations
201617_1-3A	b2930 (RPM)	Upgrade	COMED	E. Frankfort to University Park 345 kV	On Hold	06/10/2021	Upgrade capacity on E. Frankfort-University Park 345kV
201617_1-3B	b2931 (RPM)	Upgrade	COMED	Pontiac to Brokaw 345 kV	EP	06/01/2021	Upgrade substation equipment at Pontiac Midpoint station
201617_1A_R PM_DEOK	b2968 (RPM)	Upgrade	DEOK	Tanners Creek to Miami Fort 345 kV	EP	06/01/2021	Upgrade existing 345kV terminal equipment at Tanners Creek station on Tanners Creek - Miami Fort 345kV line

EP – Engineering Procurement
UC – Under Construction

2018 Acceleration Analysis

- Scope
 - Determine which reliability upgrades, if any, have an economic benefit if accelerated or modified.
- Study Years
 - 2019 and 2023 set of economic input assumptions used to study impacts of approved RTEP projects
- Process
 - Compare market congestion for near term vs. future topology
 - Estimate economic impact of accelerating planned upgrades

- Currently building the 2019 AS-IS PROMOD model
- Identifying RTEP reliability projects responsible for congestion reductions
- Acceleration analysis results to be presented at the December TEAC

- Revision History
 - V1 – 11/05/2018 – Original Version Posted to PJM.com