



# Reliability Analysis Update

Aaron Berner, Senior Manager

Transmission Expansion Advisory Committee

Tuesday, November 2, 2021

# Changes for the Existing Project

## Baseline Reliability Projects



# AEP Transmission Zone: Baseline B2668 Additional Scope

## Additional Scope for B2668 (Presented in 9/10/2015 TEAC)

B2668 was in 2015 window #1. It was proposal 2015\_1-2K, reconductor Dequine to Meadow Lake 345 kV circuit #1 utilizing dual 954 ACSR 54/7 cardinal conductor, which was the lowest cost proposal received to address the Dequine to Meadow Lake 345 kV circuit #1 overload. B2668 TEAC cost is \$5.1M

## All the proposals submitted for the violation in 2015 Window #1:

- 2015\_1-2G (\$25.6 M)
- 2015\_1-2I (\$27.5 M)
- 2015\_1-2J (\$26.6 M)
- 2015\_1-2K (\$5.1 M)
- 2015\_1-7A (\$34.2 M)

**Additional Scope Needed:** Replace the bus/risers at Dequine 345kV station (**B2668.1**).


**Estimated Cost:** \$2.3M

**Reasons for the additional scope:** During detailed engineering, AEP discovered that the bus/risers at Dequine station would limit the line after the reconductor project was completed on the Meadow Lake 1 and 2 circuits, which makes the line rating still lower than the required rating. With B2668.1, the total cost is still the lowest comparing other proposals for the cluster.

**Total Estimated Cost: \$7.4M**

**Required IS date:** 6/1/2020

**Projected IS date:** 2/28/2022





# 2021 RTEP Proposal Window



# 2021 Proposal Window 2



# ComEd Transmission Zone: 2026 Winter Sensitivity

- FGs GD-W193 and GD-W194 were placed on hold in the 2021 Window 1 as generator deactivations in ComEd not originally included in the 2026 case would relieve the overloads
- As part of a re-tool, PJM evaluated the impacts of recent deactivations requests and deactivations request withdrawals in the 2026 winter case
- PJM ran generator deliverability test using the revised 2026 winter case, and the table below shows facilities now overloaded in the updated case:

Fr Bus	Fr Name	To Bus	To Name	CKT	kVs	Areas	ContType	Rate B (MVA)	Rate C (MVA)	Final DC %LD	Final AC %LD	AC Final Flow
274750	CRETE EC ;BP	255112	17STJOHN	1	345	217/222	Single	1557	1772	114.3	118.08	1838.4
270716	DRESDEN ; B	275179	DRESDEN ;1M	1	345/138	222	Breaker	480	530	114.54	117.3	563
275179	DRESDEN ;1M	271337	DRESDEN ; R	1	138	222	Breaker	480	530	114.51	115.13	552.6

- PJM anticipates opening a window to address these issues on November 3, 2021 and close the window on January 12, 2022 (Greater than 60 days due to holiday time period)
- Notice will be sent to the TEAC list when window is opened and materials are posted



# 2021 Proposal Window 3

- The following violations are identified for PSEG FERC Form 715.  
<https://www.pjm.com/-/media/planning/planning-criteria/pseg-planning-criteria.ashx>
  - Athenia 230/138 kV transformer 220-1 → Aging
  - Fairlawn 230/138 kV transformer 220-1 → Aging
  - Lawrence 230/69 kV transformer 220-4 → Aging
- PJM anticipates opening a window to address these issues on November 3, 2021 and close the window on December 8, 2021 (Greater than 30 days due to holiday time period)
- Notice will be sent to the TEAC list when window is opened and materials are posted



# Future 2021 Proposal Window 4

- The following violation is identified for PSEG FERC Form 715.
  - Customer load increase in West Windsor area requiring additional source
    - Current source 69kV
    - Loss of  $\geq 20$  MW for  $> 24$  Hours
    - Immediate need due to required in-service date of January 1, 2023
- PJM anticipates opening a window to address these issues on December 2, 2021 and close the window on January 12, 2022 (Greater than 30 days due to holiday time period)
- Notice will be sent to the TEAC list when window is opened and materials are posted

# First Read

## Baseline Reliability Projects

**Process Stage:** First Read

**Criteria:** Generation Deliverability

**Assumption Reference:** 2026 RTEP assumption


**Model Used for Analysis:** 2026 RTEP Summer case

**Proposal Window Exclusion:** None

**Problem Statement:**

GD-S712

In 2026 RTEP summer case, the Hayes 345/138 kV xfmr # 1 is overloaded due to a tower contingency.



# ATSI Transmission Zone: Baseline

## Hayes 345/138 kV Tr#2

**Proposed solution:**


Install a second 345/138 kV transformer at Hayes, 448 MVA nameplate rating. Add one 345 kV circuit breaker (3000A) to provide transformer high side connection between breaker B-18 and the new breaker. Connect the new transformer low side to the 138 kV bus. Add one 138 kV circuit breaker (3000A) at Hayes 138 kV substation between B-42 and the new breaker. Relocate the existing 138 kV No. 1 capacitor bank between B-42 and the new breaker. Protection Per FE standard.

**Additional Benefits:** Mitigates the thermal overload on the Hayes No1 345/138 kV Transformer and provides additional capacity.

**Total Estimated Cost:** \$7.59M

**Required IS Date:** 06/01/2026

**Projected IS Date:** 06/01/2026





# AEP Transmission Zone: Baseline Delphos Area

**Process Stage:** First Read

**Criteria:** AEP FERC 715 Criteria

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP cases

**Proposal Window Exclusion:** None


**Problem Statement:**

AEP -T15, AEP -T16, AEP -T17, AEP -T18, AEP -T19, AEP -T20, AEP -T21, AEP -T22, AEP -T23, AEP -T24, AEP -T25, AEP -T26, AEP -T27, AEP -T28, AEP -T47, AEP -T48, AEP -T49, AEP -T50, AEP -T51, AEP -T52, AEP -T53, AEP -T54, AEP -T55, AEP -T56, AEP -T57, AEP -T58, AEP -T73, AEP -T74, AEP -T75, AEP -T76

In 2026 RTEP summer, winter and light load cases, the North Delphos – East Delphos 69kV line and the East Delphos – Elida Road 69kV line are overloaded for multiple N-1-1 contingency pairs. The North Delphos – East Delphos 69kV line and the Delphos – South Delphos are overload for a N-1-1 contingency pair.

**Existing Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
05N DELPHO – 05E DELPHO 69KV	46/46/56/56
05E DELPHO – 05ELIDA ROAD 69KV	46/46/56/56
05DELPHO – 05S DELPHO 69KV	50/50/63/63
05N DELPHO – 05S DELPHO 69KV	54/54/76/76



**SN / SE / WN / WE:** Summer Normal / Summer Emergency / Winter Normal / Winter Emergency



As part of the 2021 RTEP Window #1, the projects listed in the table below are proposed to address the following violations: AEP -T15, AEP -T16, AEP -T17, AEP -T18, AEP -T19, AEP -T20, AEP -T21, AEP -T22, AEP -T23, AEP -T24, AEP -T25, AEP -T26, AEP -T27, AEP -T28, AEP -T51, AEP -T52, AEP -T53, AEP -T54, AEP -T73, AEP -T74, AEP -T75, AEP -T76

(NOTE: Proposal 202 and 786 additionally addresses: AEP -T47, AEP -T48, AEP -T49, AEP -T50, AEP -T55 , AEP -T56, AEP -T57, AEP -T58 )

Proposal ID	Proposing Entity	Upgrade Description	Upgrade Cost (\$M)
202	AEP	Delphos Area Line Rebuilds	8.871
786	AEP	Haviland Sectionalizing Addition (Plus convert s2389 to baseline)	1.309 (plus \$65.36M for s2389 conversion)
503	CNTLTM	LS Rockford - LS West Van Wert 69kV Transmission Project	14.415

**Proposed Solution:** Proposal #2021\_1-202

- Rebuild approximately 3.5 miles of overloaded 69 kV line between North Delphos-East Delphos-Elida Road switch. This includes approximately 1.1 miles of double circuit line that makes up a portion of the North Delphos-South Delphos 69 kV line and the North Delphos-East Delphos 69 kV line. Approximately 2.4 miles of single circuit line will also be rebuilt between the double circuit portion to East Delphos station and from East Delphos to Elida Road Switch. Estimated cost: \$8.434M
- Replace the line entrance spans at South Delphos to eliminate the overloaded 4/0 Copper and 4/0 ACSR conductor. Estimated cost: \$0.437M

**Total Estimated Cost: \$8.871M**

# AEP Transmission Zone: Baseline Delphos Area


**Additional Benefit:** The lines that are will addressed on the proposal include: One mile of the 5.26 mile North Delphos – South Delphos 69kV line asset consists of 22 wood pole structures, originally installed in 1943 primarily with 2/0 COPPER 7 (20COP) conductor. The line asset is part of two circuits: North Delphos – Van Wert 69kV and North Delphos-West Moulton 69kV circuits. There are currently 7 open conditions specifically affecting the 1 mile section of the line The Delphos Junction – East Delphos 69kV Line asset is 2.29 miles long and consists of wood pole structures, originally installed in 1939 primarily with 2/0 COPPER 7 (2/0COP) conductor. There are 40 structures with at least one open condition, which relates to 74% of the structures on the line. There are 36 open conditions related to broken or missing ground lead wires which could lead to the poor lightning performance. There are currently 9 structure related open conditions specifically affecting the Knee/Vee Brace (broken/rot).

**Preliminary Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
05N DELPHO – 05E DELPHO 69KV	68/71/71/71
05E DELPHO – 05ELIDA ROAD 69KV	82/90/107/113
05DELPHO – 05S DELPHO 69KV	73/73/91/91
05N DELPHO – 05S DELPHO 69KV	68/73/90/91

**Required IS Date: 6/1/2026**

**Projected IS Date: 6/1/2026**



**SN / SE / WN / WE:** Summer Normal / Summer Emergency / Winter Normal / Winter Emergency



# AEP Transmission Zone: Baseline Dehue Area

**Process Stage:** First Read

**Criteria:** AEP FERC 715 Criteria

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP cases

**Proposal Window Exclusion:** None

**Problem Statement:**

AEP -T6, AEP -T7, AEP -T8


In 2026 RTEP light load case, the Becco – Slagle 46kV line, the Dehue – Pine Gap 46kV line and Dehue – Slagle 46kV line are overload for a N-1-1 contingency pair.

AEP-VM1, AEP-VM2, AEP-VM3, AEP-VM4, AEP-VM5, AEP-VM6, AEP-VM7, AEP-VM8, AEP-VM9, AEP-VD1, AEP-VD2, AEP-VD3, AEP-VD4, AEP-VD5, AEP-VD6, AEP-VD7, AEP-VD8, AEP-VD9 (excluded from Window due to <200KV exclusion).

Low voltage and voltage drop violations at Three Fork, Toney Fork, Cyclone, Pardee, Crane,, Latrobe, Becco, Slagle, Dehue 46kV buses for a N-1-1 contingency pair.

**Existing Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
05BECCO – 05SLAGLE 46KV	23/23/32/32
05DEHUE– 05SLAGLE 46KV	23/23/32/32
05DEHUE – 05PINE GAP 46KV	27/27/34/34



**SN / SE / WN / WE:** Summer Normal / Summer Emergency / Winter Normal / Winter Emergency



As part of the 2021 RTEP Window #1, the projects listed in the table below are proposed to address the following violations: AEP -T6, AEP -T7, AEP -T8, AEP-VM1, AEP-VM2, AEP-VM3, AEP-VM4, AEP-VM5, AEP-VM6, AEP-VM7, AEP-VM8, AEP-VM9, AEP-VD1, AEP-VD2, AEP-VD3, AEP-VD4, AEP-VD5, AEP-VD6, AEP-VD7, AEP-VD8, AEP-VD9

Proposal ID	Proposing Entity	Upgrade Description	Upgrade Cost (\$M)
365	AEP	Accoville-Becco 69 kV	13.048
310	AEP	Becco-Pine Gap Rebuild	50.191
488	AEP	Dehue Expansion and Line Rebuilds	65.798

### Proposed Solution: Proposal #2021\_1-488

- Construct a 138kV single bus station (Tin Branch) consisting of a 138kV box bay with a distribution transformer and 12kV distribution bay. Two 138kV lines will feed this station (from Logan and Sprigg Stations), and distribution will have one 12kV feed. Install two 138 kV circuit breakers on the line exits. Install 138 kV circuit switcher for the new transformer. Estimated cost: \$5.584M
- Construct a new 138/46/12 kV Argyle station to replace Dehue station. Install a 138kV ring bus using a breaker-and-a-half configuration, with an autotransformer with a 46kV feed and a distribution transformer with a 12kV distribution bay. Two 138kV lines will feed this station (from Logan and Wyoming Stations). There will also be a 46kV feed from this station to Becco Station. Distribution will have two 12kV feeds. Retire Dehue station in its entirety. Estimated cost: \$9.996M
- Bring the Logan - Sprigg #2 138kV circuit in and out of Tin Branch station by constructing approximately 1.75 miles of new overhead double circuit 138kV line. Double circuit T3 series lattice towers will be used along with 795,000cm ACSR 26/7 conductor. One shield wire will be conventional 7 #8 ALUMOWELD and one shield wire will be OPGW. Estimated cost: \$8.578M
- Logan - Wyoming No. 1 circuit in and out of the proposed Argyle Station. Double circuit T3 series lattice towers will be used along with 795,000cm ACSR 26/7 conductor. One shield wire will be conventional 7 #8 ALUMOWELD and one shield wire will be OPGW. Estimated cost: \$7.702M
- Rebuild approximately 10 miles of 46 kV line between Becco and the new Argyle substation. Retire approximately 16 miles of 46 kV line between the new Argyle substation and Chauncey station. Estimated cost: \$33.705M
- Adjust relay settings due to new line terminations and retirements at Logan, Wyoming, Sprigg, Becco, and Chauncey stations. Estimated cost: \$0.233M

**Total Estimated Cost: \$65.798M**

**Additional Benefit:**

- This project will also address the needs reviewed with stakeholders under need number AEP-2020-AP044 in the November 20, 2020 W-SRRTEP.
- This project will also address the asset performance, condition, and risk needs on the Chauncey - Pine Gap 46kV Line which is a 1937 vintage wood pole line with 29 open structure conditions with 59% of the structures along the line with at least one open condition.
- This proposal, by constructing approximately 3.5 miles of greenfield 138 kV line and two new stations, allows for the retirement of over 15 miles of deteriorating 46 kV line in very challenging territory, helping to reduce future rebuild investment required to address asset renewal needs on the 46 kV system.
- This project will also address the asset performance, condition, and risk needs at Pine Gap 46kV station:
  - Transformer #1 is a 46/12kV 1949s vintage bank. The transformer has high levels of acetylene, decreasing and low interfacial tension (IFT), and high and rising moisture levels. These levels indicate increased decomposition of the paper insulating materials and indicate that electrical discharges have been occurring within the main tank. The insulation is shrinking and weakening. This is an indication of an aged oil with polar contaminants and oxidation byproducts. The values of IFT and moisture indicate the dielectric strength of the insulation system (oil and paper) is in poor condition. The oil containment is extremely deteriorated with the lining visible above the station stone.
  - Pine Gap Substation currently deploys 16 relays, implemented to ensure the adequate protection and operation of the substation. Currently, all 16 relays are in need of replacement. All 16 of these are of the electromechanical and static type which have significant limitations with regards to spare part availability and fault data collection and retention. In addition, these relays lack vendor support. The existing control house lacks enough panel space to accommodate new relaying.




# AEP Transmission Zone: Baseline Dehue Area

## Preliminary Facility Rating:

Branch	SN/SE/WN/WE (MVA)
05LOGAN1– 05ARGYLE 138KV	257/360/325/404
05RUMCKZ – 05ARGYLE 138KV	257/360/325/404
05ARGYLE 138/69/46KV 1st winding	90/90/90/90
05ARGYLE 138/69/46KV 2nd winding	90/90/90/90
05ARGYLE 138/69/46KV 3rd winding	60/60/60/60

Required IS Date: 11/1/2026  
 Projected IS Date: 6/30/2026



SN / SE / WN / WE: Summer Normal / Summer Emergency / Winter Normal / Winter Emergency



# APS Transmission Zone: Baseline Shingletown 230 kV

**Process Stage:** First Read

**Criteria:** PJM N-1-1 Criteria

**Assumption Reference:** 2026 RTEP assumption


**Model Used for Analysis:** 2026 RTEP Summer case

**Proposal Window Exclusion:** None

**Problem Statement:**

APS-VD45 & APS-VD46

In 2026 RTEP summer case, the Shingletown 230 kV voltage drop violation occurs due to a N-1-1 contingency.





# APS Transmission Zone: Baseline Shingletown 230 kV

As part of the 2021 RTEP Window # 1, the projects listed below are proposed to address the voltage drop APS-VD45 & APS-VD46 violations.

Proposal ID	Proposing Entity	Upgrade Description	Upgrade Cost (\$M)
919	West Penn	Upgrade the Shingletown #82 230-46 kV Transformer Circuit by installing a 230 kV breaker.	1.66
779	West Penn	Convert Shingletown 230 kV Substation into a six-breaker ring bus.	11.92
608	CNTLTM	Tapping the Dale - Milesburg 230kV transmission line and creating a new substation named Persia. Connect the new Persia substation to the Yeagertown substation by creating a new 230 kV line.	77.59
560	CNTLTM	Tapping the Dale - Milesburg 230kV transmission line and creating a new substation named Persia. Connect the new Persia substation to the Elimsport substation by creating a new 230 kV line.	135.54

Upgrade the Shingletown #82 230-46 kV Transformer Circuit by installing a 230 kV breaker and disconnect switches, removing existing 230 kV switches, replacing 46 kV disconnect switches, replacing limiting substation conductor, and installing/replacing relays.

**Total Estimated Cost: \$1.66M**

**Required IS Date: 06/01/2026**

**Projected IS Date: 06/01/2025**





As part of the 2021 RTEP Window #1, the following projects were proposed to address violations on 230kV Line #2114:

Proposal ID	Proposing Entity	Upgrade Description	Upgrade Cost (\$M)
445	Dominion	Line #2114 Remington CT to Gainesville full reconductor. Upgrade wave trap and substation conductor at both terminals. Upgrade Brambleton breakers.	30.680
333	Dominion	Line #2114 Remington CT to Gainesville full reconductor. Upgrade terminal equipment at both ends to include 230kV circuit breakers, switches and leads to achieve 4000A rating. Upgrade Brambleton breakers.	39.693
298 <sup>(1)</sup>	TRNSRC	Construct greenfield Lee District 500 kV station with 6-breaker ring bus.	72.876

<sup>(1)</sup>Proposal 298 also addresses Generator Deliverability violation GD-S30. (This flowgate was eliminated as a result of the 2021 RTEP re-tool).

**Proposed Solution:** Proposal #2021\_1-445

- Reconductor approximately 24.42 miles of 230kV Line #2114 Remington CT - Elk Run - Gainesville to achieve a summer rating of 1574 MVA by fully reconductoring the line and upgrading the wave trap and substation conductor at Remington CT and Gainesville. **Estimated cost: \$28.988M**
- Replace 230 kV breakers SC102, H302, H402, and 218302 at Brambleton substation with 4000A 80kA breakers and associated equipment including breaker leads as necessary to address breaker duty issues identified in short circuit analysis. **Estimated cost: \$1.692M**

**Total Estimated Cost: \$30.680M**

**Required IS Date: 6/1/2026**



# Dominion Transmission Zone: Baseline Cub Run - Walney

**Process Stage:** First Read

**Criteria:** N-1

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP cases

**Proposal Window Exclusion:** None

**Problem Statement:**

N1-ST33


In the 2026 RTEP summer case, 230kV Line #2008 Cub Run to Walney is overloaded for a breaker contingency under N-1.

**Existing Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
6CUBRUN – 6WALNEY 230KV	823/823/944/944

Continued on next slide....

**SN / SE / WN / WE:** Summer Normal / Summer Emergency / Winter Normal / Winter Emergency





# Dominion Transmission Zone: Baseline Cub Run - Walney

As part of the 2021 RTEP Window #1, the following project was proposed to address violations on 230kV Line #2008:

Proposal ID	Proposing Entity	Upgrade Description	Upgrade Cost (\$M)
600	Dominion	Line #2008 Cub Run to Walney reconductor. Replace line switch 200826 with a 4000A switch.	1.934

**Proposed Solution:** Proposal #2021\_1-600

- Reconductor approximately 1.07 miles of 230kV Line #2008 segment from Cub Run – Walney to achieve a summer rating of 1574 MVA. Replace line switch 200826 with a 4000A switch.

**Total Estimated Cost: \$1.934M**

**Required IS Date: 6/1/2026**



# Dominion Transmission Zone: Baseline Lakeview - Carolina

**Process Stage:** First Read

**Criteria:** Generator Deliverability

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP cases

**Proposal Window Exclusion:** None

**Problem Statement:**

GD-S19


In the 2026 RTEP summer case, 230kV Line #2141 Lakeview to Carolina is overloaded for a single contingency under Generator Deliverability.

**Existing Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
6LAKEVEW – 6CAROLNA 230kV	399/399/505/505

Continued on next slide....

**SN / SE / WN / WE:** Summer Normal / Summer Emergency / Winter Normal / Winter Emergency





# Dominion Transmission Zone: Baseline Lakeview - Carolina

As part of the 2021 RTEP Window #1, the following project was proposed to address violations on 230kV Line #2141:

Proposal ID	Proposing Entity	Upgrade Description	Upgrade Cost (\$M)
414	Dominion	Line #2141 Lakeview to Carolina reconductor	1.185

**Proposed Solution:** Proposal #2021\_1-414

- Reconductor approximately 1.4 miles of 230kV Line #2141 from Lakeview – Carolina to achieve a summer rating of 1047 MVA.

**Total Estimated Cost: \$1.185M**

**Required IS Date: 6/1/2026**



# Dominion Transmission Zone: Baseline Elmont - Chickahominy

**Process Stage:** First Read

**Criteria:** FERC Form 715 (C.2.9 End-of-Life Criteria)

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP cases

**Proposal Window Exclusion:** None

**Problem Statement:**

DOM-02


500kV Line #557 Elmont to Chickahominy was constructed in 1971 with ACAR conductor and 5-series Corten towers that need to be rebuilt to current standards based on Dominion's End-of-Life Criteria.

**Existing Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
8ELMONT – 8CHCKAHM 230kV	2598/2598/2988/3014

Continued on next slide....

**SN / SE / WN / WE:** Summer Normal / Summer Emergency / Winter Normal / Winter Emergency





# Dominion Transmission Zone: Baseline Elmont - Chickahominy

As part of the 2021 RTEP Window #1, the following projects was proposed to address violations on 500kV Line #557:

Proposal ID	Proposing Entity	Upgrade Description	Upgrade Cost (\$M)
124	Dominion	Line #557 Elmont to Chickahominy reconductor	58.155

**Proposed Solution:** Proposal #2021\_1-124

- Rebuild approximately 27.7-miles of 500 kV transmission line from Elmont to Chickahominy with current 500 kV standards construction practices to achieve a summer rating of 4330 MVA.

**Total Estimated Cost: \$58.155M**

**Required IS Date: 6/1/2026**



# Dominion Transmission Zone: Baseline Lexington & Bath County 500kV

**Process Stage:** First Read

**Criteria:** N-1 Voltage Magnitude & Drop

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP cases


**Proposal Window Exclusion:** None

**Problem Statement:**

N1-LLVM1, N1-LLVM2, N1-LLVM3, N1-LLVM4, N1-LLVM5, N1-LLVM6, N1-LLVM7, N1-LLVM8, N1-LLVD1, N1-LLVD2, N1-LLVD3

In the 2026 RTEP light load case, there are voltage magnitude and voltage drop violations at the 500kV buses of Lexington and Bath County for single and breaker contingencies under N-1.

Continued on next slide....





# Dominion Transmission Zone: Baseline Lexington & Bath County 500kV

As part of the 2021 RTEP Window #1, the following project was proposed to address violations at Lexington and Bath County 500kV:

Proposal ID	Proposing Entity	Upgrade Description	Upgrade Cost (\$M)
722	Dominion	Install 294 MVar Cap Bank at Lexington substation	5.860

**Proposed Solution:** Proposal #2021\_1-722

- Expand substation and install approximately 294 MVar cap bank at 500kV Lexington substation along with a 500kV breaker. Adjust the tap positions associated with the two 230/69kV transformers at Harrisonburg to neutral position and lock them.

**Total Estimated Cost: \$5.860M**

**Required IS Date: 6/1/2026**

**SN / SE / WN / WE:** Summer Normal / Summer Emergency / Winter Normal / Winter Emergency



# Dominion Transmission Zone: Baseline Ox 500/230kV Transformers

**Process Stage:** First Read

**Criteria:** FERC Form 715 (C.2.1.3 Critical Stress Case)

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP cases

**Proposal Window Exclusion:** None

**Problem Statement:**

DOM-T3, DOM-T4


In the 2026 RTEP summer case, the Ox 500/230kV transformer #1 & Ox 500/230kV transformer #2 are overloaded under Dominion stress case criteria. (Outage of the most critical generator followed by single contingency: N-1-1).

**Existing Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
8OX – 6OX #1 500/230kV	931.9/963.8/1198.8/1242.3
8OX – 6OX #2 500/230kV	909.3/951.9/1167.6/1220.4

Continued on next slide....

**SN / SE / WN / WE:** Summer Normal / Summer Emergency / Winter Normal / Winter Emergency



COLOR	VOLTAGE	TRANSMISSION LINE NUMBER
Green	500 KV.	500 thru 599
Blue	230 KV.	200 thru 299 & 2000 thru 2099
Red	115 KV.	1 thru 199
Orange	138 KV.	AS NOTED
Cyan	69 KV.	AS NOTED



# Dominion Transmission Zone: Baseline Ox 500/230kV Transformers

As part of the 2021 RTEP Window #1, the following projects were proposed to address violations on 500/230kV transformer #1 & #2 at Ox:

Proposal ID	Proposing Entity	Upgrade Description	Upgrade Cost (\$M)
57 <sup>(1)</sup>	Dominion	Install 2 <sup>nd</sup> 500/230kV transformer at Possum Point	24.539
319	Dominion	Replace both 500/230kV transformers at Ox	63.768
637	Dominion	Expand Occoquan substation via the installation of a 500kV GIS ring bus, 1-1100MVA 500/230kV transformer and 230kV breaker-and-a-half bus arrangement.	75.389

(1) Proposal 57 corresponds to baseline B2443.6 that was canceled. (Adding 2nd 500/230kV transformer at Possum Point.)

### Proposed Solution: Proposal #2021\_1-57

- Install a 2nd 500kV-230kV 840MVA transformer bank at Possum Point 500kV yard, a 0.8 mile long 230kV line extension between Possum Point 500kV and Possum Point 230kV substation, and a new 230kV breaker at Possum 230kV yard to terminate the extension. Note: Possum Point 500kV Substation and Possum Point 230kV Substation are separated by approximately 0.85 miles.

**Total Estimated Cost: \$24.539M**

**Required IS Date: 6/1/2026**



# Dominion Transmission Zone: Baseline Fredericksburg/Carson/Hopewell Area

**Process Stage:** First Read

**Criteria:** Generator Deliverability, FERC Form 715 (C.2.1.3 Critical Stress Case) & N-1

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP cases

**Proposal Window Exclusion:** None

**Problem Statement:**

In the 2026 RTEP summer case:

Fredericksburg (Group 1: N2-SLD1, N2-SLD2, GD-S16, GD-S467, DOM-T5)

- 230kV Line #2104 Cranes Corner to Stafford is overloaded for a single and breaker contingency under Generator Deliverability and is also overloaded under Dominion stress case criteria.
- Load loss of 307 MW under N-1-1.

Carson (Group 2: GD-S465, GD-S39)

- Carson 500/230kV transformer #2 is overloaded for a breaker contingency under Generator Deliverability.
- 230kV Line #249 Carson to Chaparral is overloaded for a single contingency under Generator Deliverability.

Hopewell (Group 3: GD-S18, GD-S33, GD-S436)

- 230kV Line #211 is overloaded for a single contingency under Generator Deliverability.
- 230kV Line #228 is overloaded for a single and breaker contingency under Generator Deliverability.

Continued on next slide....

COLOR	VOLTAGE	TRANSMISSION LINE NUMBER
Green	500 KV.	500 thru 599
Blue	230 KV.	200 thru 299 & 2000 thru 2099
Red	115 KV.	1 thru 199
Orange	138 KV.	AS NOTED
Cyan	69 KV.	AS NOTED





# Dominion Transmission Zone: Baseline Fredericksburg/Carson/Hopewell Area

## Existing Facility Rating:

Area	Branch	SN/SE/WN/WE (MVA)
Fredericksburg	6CRANES – 6STAFORD 230kV	722/722/914/914
Carson	8CARSON – 6CARSON 500kV	928.1/961.6/1192.8/1238.1
Carson	6CARSON – 6CHAPARRAL T 230kV	595/595/659/659
Carson	6LOCKS – 6CHAPARRAL T 230kV	595/595/659/659
Carson	6LOCKS – 3HARROWG 115kV	147/147/185/185
Hopewell	6HOPEWLL – 6CHESTF A 230kV	478/478/606/606
Hopewell	6HOPEWLL – 6CHESTF B 230kV	478/478/606/606

As part of the 2021 RTEP Window #1, the following project was proposed to address violations at Fredericksburg, Carson and Hopewell:

Proposal ID	Proposing Entity	Upgrade Description	Upgrade Cost (\$M)
224	Dominion	<p><b>Fredericksburg:</b> Convert 115kV Line #29 to 230 kV; Reconductor 230kV Line #2104 Cranes Corner to Aquia Harbor. Feed Quantico via Fuller Road Substation</p> <p><b>Carson:</b> Energize Carson 500/230kV Tx#1; Reconductor 230kV Line #249 Carson to Locks; Partial Rebuild 115kV Line #100 Locks to Harrowgate</p> <p><b>Hopewell:</b> Partial rebuild 2.9 miles of double circuit 230kV Lines #211/228</p>	93.412

Continued on next slide...



# Dominion Transmission Zone: Baseline Fredericksburg/Carson/Hopewell Area

**Proposed Solution:** Proposal #2021\_1-224

## Fredericksburg

- Convert Line #29 Aquia Harbor to Possum Point to 230 kV (Extended Line #2104) and swap Line #2104 and converted Line #29 at Aquia Harbor backbone termination. Upgrade terminal equipment at Possum Point to terminate converted Line 29 (now extended Line #2104). (Line #29 from Fredericksburg to Aquia Harbor is being rebuilt under baseline b2981 to 230kV standards.) **Estimated cost: \$9.386M**
- Upgrade Aquia Harbor terminal equipment to not limit 230kV Line #9281 conductor rating. **Estimated cost: \$0.631M**
- Upgrade Fredericksburg terminal equipment by rearranging 230 kV bus configuration to terminate converted Line 29 (now becoming 9281). The project will add a new breaker at the 230kV bay and reconfigure line termination of 230kV Lines #2157, #2090, and #2083. **Estimated cost: \$2.725M**
- Reconductor/rebuild approximately 7.6 miles of 230kV Line #2104 Cranes Corner – Stafford to achieve a summer rating of 1047 MVA<sup>(1)</sup>. Reconductor/rebuild approximately 0.34 miles of 230kV Line #2104 Stafford – Aquia Harbor to achieve a summer rating of 1047 MVA. Upgrade terminal equipment at Cranes Corner to not limit the new conductor rating. **Estimated cost: \$19.596M**
- Upgrade wave trap and line leads at 230kV Line #2090 Ladysmith CT terminal to achieve 4000A rating. **Estimated cost: \$0.152M**
- Upgrade Fuller Road substation to feed Quantico substation via 115 kV radial line. Install four breaker ring and break 230kV Line #252 into two new lines: 1) #252 between Aquia Harbor to Fuller Road and 2) #9282 between Fuller Road and Possum Point. Install a 230/115 kV transformer which will serve Quantico substation. **Estimated cost: \$24.159M**

<sup>(1)</sup> This portion of the project will be addressed by baseline b3321 as it overlaps the violation associated with the deactivation of Morgantown 1 and 2 presented at the 8/31 TEAC.

Continued on next slide....





# Dominion Transmission Zone: Baseline Fredericksburg/Carson/Hopewell Area

**Proposed Solution:** Proposal #2021\_1-224

## Carson

- Energize in-service spare 500/230kV Carson Tx#1
- Partial wreck and rebuild 10.34 miles of 230kV Line #249 Carson - Locks to achieve a minimum summer emergency rating of 1047 MVA. Upgrade terminal equipment at Carson and Locks to not limit the new conductor rating. **Estimated cost: \$15.365M**
- Wreck and rebuild 5.4 miles of 115kV Line #100 Locks - Harrowgate to achieve a minimum summer emergency rating of 393 MVA. Upgrade terminal equipment at Locks and Harrowgate to not limit the new conductor rating and perform Line #100 Chesterfield terminal relay work. **Estimated cost: \$9.097M**

## Hopewell

- Reconductor approximately 2.9 miles of 230 kV Line #211 Chesterfield – Hopewell to achieve a minimum summer emergency rating of 1046 MVA. **Estimated cost: \$4.914M**
- Reconductor approximately 2.9 miles of 230 kV Line #228 Chesterfield - Hopewell to achieve a minimum summer emergency rating of 1046 MVA. **Estimated cost: \$4.914M**
- Upgrade equipment at Chesterfield substation to not limit ratings on Lines 211 and 228. **Estimated cost: \$0.759M**
- Upgrade equipment at Hopewell substation to not limit ratings on Lines 211 and 228. **Estimated cost: \$1.714M**

**Total Estimated Cost: \$93.412M**

**Required IS Date: 6/1/2026**

# Second Review

## Baseline Reliability Projects

# AEP Transmission Zone: Baseline Muskingum-Waterford 345 kV Bus/Riser Upgrades

**Process Stage:** Second Review

**Criteria:** Generator Deliverability

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP cases

**Proposal Window Exclusion:** Substation Equipment Exclusion


**Problem Statement:**

FG: GD-S419

In 2026 Summer Gen Deliv test, the Waterford – Muskingum 345kV line is overloaded for a breaker contingency.

**Existing Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
05WATERFORD – 05MUSKNG 345KV	1025/1318/1298/1522 for certain contingencies



# AEP Transmission Zone: Baseline Muskingum-Waterford 345 kV Bus/Riser Upgrades

## Recommended Solution:

Replace the 2156 ACSR & 2874 ACSR bus and risers with 2-bundled 2156 ACSR at Muskingum River 345 kV station to address loading issues on Muskingum - Waterford 345 kV line. (B3342)

**Total Estimated Cost: \$0.53M**

## Preliminary Facility Rating:


Branch	SN/SE/WN/WE (MVA)
05WATERFORD – 05MUSKNG 345KV	1868/1868/2315/2315

**Ancillary Benefit:** This proposal also addresses a portion of supplemental need AEP-2020-AEP001

**Required IS date:** 6/1/2026

**Projected IS date:** 9/1/2025

**Previously Presented:** 10/5/2021





# AEP Transmission Zone: Baseline Albion-Kendallville Rebuild

**Process Stage:** Second Review

**Criteria:** AEP FERC 715 Criteria

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP cases

**Proposal Window Exclusion:** None


**Problem Statement:**

AEP-T43, AEP-T44, AEP-T45, AEP-T46

In 2026 RTEP summer case, the Albion - Philips Switch and Philips Switch - Brimfield Switch 69kV line are overloaded for multiple N-1-1 contingency pairs.

**Existing Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
05BRIMFLD8 – 05PHILOPSZ 69KV	50/50/63/63
05PHILOPSZ – 05ALBION Z 69KV	50/50/63/63



**SN / SE / WN / WE:** Summer Normal / Summer Emergency / Winter Normal / Winter Emergency



# AEP Transmission Zone: Baseline Albion-Kendallville Rebuild

As part of the 2021 RTEP Window #1, the projects listed in the table below are proposed to address the following violations: AEP-T43, AEP-T44, AEP-T45, AEP-T46

Proposal ID	Proposing Entity	Upgrade Description	Upgrade Cost (\$M)
25	AEP	Albion-Kendallville Rebuild	0.61

**Recommended Solution:** Proposal #2021\_1-25: Rebuild approximately 0.3 miles of overloaded 69 kV line between Albion - Philips Switch and Philips Switch - Brimfield Switch with 556 ACSR conductor. (B3343)

**Estimated Cost: \$0.61M**

**Preliminary Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
05BRIMFLD8 – 05PHILOPSZ 69KV	82/90/107/113
05PHILOPSZ – 05ALBION Z 69KV	82/90/107/113


**Required IS Date:** 6/1/2026

**Required IS Date:** 6/1/2026

**Previously Presented:** 10/5/2021

**SN / SE / WN / WE:** Summer Normal / Summer Emergency / Winter Normal / Winter Emergency

# AEP Transmission Zone: Baseline Albion-Kendallville Rebuild



Legend	
500 kV	
345 kV	
138 kV	
69 kV	
34.5 kV	
23 kV	
New	




# AEP Transmission Zone: Baseline West Kingsport Area

**Process Stage:** Second Review  
**Criteria:** AEP FERC 715 Criteria  
**Assumption Reference:** 2026 RTEP assumption  
**Model Used for Analysis:** 2026 RTEP cases  
**Proposal Window Exclusion:** None

### Problem Statement:

AEP -T1, AEP -T2, AEP -T3, AEP -T4, AEP -T5

In 2026 RTEP light load case, the Lovedale – Sewage 34.5kV line and the Sewage – West Kingsport 34.5kV lines are overloaded for the N-1-1 contingency pair; and the West Kingsport transformer is overloaded for multiple N-1-1 contingency pairs.





As part of the 2021 RTEP Window #1, the projects listed in the table below are proposed to address the following violations: AEP-T1, AEP-T1, AEP-T3, AEP-T4, AEP-T5

Proposal ID	Proposing Entity	Upgrade Description	Upgrade Cost (\$M)
19	AEP	West Kingsport Line Cut In	2.907
909	AEP	West Kingsport Transformer Replacement and Line Rebuilds	7.425

**Recommended Solution:** Proposal #2021\_1-19

- Install two (2) 138 KV circuit breakers in the M and N strings in the breaker-and-a half configuration in West Kingsport station 138 KV yard to allow the Clinch River – Moreland Dr. 138 KV to cut in the West Kingsport station (**B3344.1**), Estimated Cost: \$1.846 M
- Upgrade remote end relaying at Riverport 138kV station due to the line cut in at West Kingsport station (**B3344.2**), Estimated Cost: \$0.251M


**Total Estimated Cost: \$2.097M**

**Required IS Date:** 11/1/2026

**Required IS Date:** 11/1/2026


**Previously Presented:** 10/5/2021

**Existing:**



Legend	
500 kV	
345 kV	
138 kV	
69 kV	
34.5 kV	
23 kV	
New	

**Proposed:**



# AEP Transmission Zone: Baseline Leatherwood – Salt Fork 69kV line

**Process Stage:** Second Review

**Criteria:** AEP FERC 715 Criteria

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP cases

**Proposal Window Exclusion:** None


**Problem Statement:**

AEP-T39, AEP-T40, AEP-T41, AEP-T42

In 2026 RTEP summer case, the Leatherwood – Broom Road 69kV line and Broom Road – Salt Fork 69kV line are overloaded for a N-1-1 contingency pair.

**Existing Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
05LEATHERW – 05BROOMRD 69KV	46/46/60/60
05BROOMRD – 05SALTFRKZ 69KV	46/46/60/60



**SN / SE / WN / WE:** Summer Normal / Summer Emergency / Winter Normal / Winter Emergency



# AEP Transmission Zone: Baseline Leatherwood – Salt Fork 69kV line

As part of the 2021 RTEP Window #1, the projects listed in the table below are proposed to address the following violations: AEP-T39, AEP-T40, AEP-T41, AEP-T42

Proposal ID	Proposing Entity	Upgrade Description	Upgrade Cost (\$M)
115	AEP	Salt Fork-Leatherwood Rebuild	9.101
920	AEP	West Cambridge Transformer Addition	4.953

**Recommended Solution:** Proposal #2021\_1-115

- Rebuild ~4.2 miles of overloaded sections of the 69 kV line between Salt Fork Switch and Leatherwood Switch with 556 ACSR. **(B3345.1)** Estimated cost: \$9.062M
- Update relay settings at Broom Road station. **(B3345.2)** Estimated cost: \$0.039M

**Estimated Cost: \$9.101M**

**Additional Benefit:** Addresses part of the supplemental need AEP-2021-OH006 (presented in 2/17/2021 W-SRRTEP)

Branch	SN/SE/WN/WE (MVA)
05LEATHERW – 05BROOMRD 69KV	73/90/91/106
05BROOMRD – 05SALTFRKZ 69KV	73/73/91/91


**Required IS Date:** 6/1/2026

**Required IS Date:** 6/1/2026

**Previously Presented:** 10/5/2021


**SN / SE / WN / WE:** Summer Normal / Summer Emergency / Winter Normal / Winter Emergency

Existing:



Legend	
500 kV	
345 kV	
138 kV	
69 kV	
34.5 kV	
23 kV	
New	

Proposed:







# AEP Transmission Zone: Baseline Bancroft-Milton 69kV line

As part of the 2021 RTEP Window #1, the projects listed in the table below are proposed to address the following violations: AEP -T9, AEP -T10, AEP -T11, AEP -T12, AEP -T13, AEP -T14

Proposal ID	Proposing Entity	Upgrade Description	Upgrade Cost (\$M)
116	AEP	Bancroft-Milton Rebuild	56.729
336	AEP	Cabell Station Expansion and Cut In	13.684

### Recommended Solution: Proposal #2021\_1-116

- Rebuild approximately 20 miles of line between Bancroft and Milton stations with 556 ACSR conductor. **(B3347.1)** Estimated cost: \$56.553M
- Replace the jumpers around Hurricane switch with 556 ACSR. **(B3347.2)** Estimated cost: \$0.014M
- Replace the jumpers around Teays switch with 556 ACSR.. **(B3347.3)** Estimated cost: \$0.014M
- Winfield Station Relay Settings: Update relay settings to coordinate with remote ends on line rebuild. **(B3347.4)** Estimated cost: \$0.047M
- Bancroft Station Relay Settings: Update relay settings to coordinate with remote ends on line rebuild. **(B3347.5)** Estimated cost: \$0.027M
- Milton Station Relay Settings: Update relay settings to coordinate with remote ends on line rebuild. **(B3347.6)** Estimated cost: \$0.027M
- Putnam Village Station Relay Settings: Update relay settings to coordinate with remote ends on line rebuild. **(B3347.7)** Estimated cost: \$0.047M

**Total Estimated Cost: \$56.729M**



# AEP Transmission Zone: Baseline Bancroft-Milton 69kV line

**Additional Benefit:** The Bancroft - Milton 69 kV line is mostly comprised of 1920s and 1930s steel lattice construction and has experienced 28 momentary outages and 10 permanent outages since 2015, resulting in 840,000 CMI. Any supplemental needs not addressed in this proposal will go through the M-3 process as needed.

**Preliminary Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
05HURRICAN – 05MILTON 69KV	102/142/129/159
05HURRICAN – 05TEAYS 69KV	102/142/129/159
05TEAYS – 05PUTNAM VLG 69KV	102/142/129/159
05WINFIELD – 05PUTNAM VLG 69KV	102/142/129/159
05BANCROFT – 05PUTNAM VLG 69KV	102/142/129/159

**Required IS Date:** 11/1/2026  
**Projected IS Date:** 6/30/2026  
**Previously Presented:** 10/5/2021

**Existing**



**Proposed**



Legend	
345 kV	
138 kV	
69 kV	
46 kV	
New	

**SN / SE / WN / WE:** Summer Normal / Summer Emergency / Winter Normal / Winter Emergency



# PECO Transmission Zone: Baseline

**Process Stage:** Second Review

**Criteria:** Summer Generator Deliverability

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP Summer case

**Proposal Window Exclusion:** None

**Problem Statement:**

The PECO portion of the Croydon – Burlington 230 kV circuit is overloaded for multiple contingencies.

Violations were posted as part of the 2021 Window 1: FG# GD-S485, GD-S674 and GD-S486

**Existing Facility Rating:** 752SN/906E, 840WN/996WE MVA

**Proposed Facility Rating:** 851SN/995SE, 892WN/1020WE MVA

**Recommended Solution:**

**Proposal ID 88-** Replace a 0.76 mile length of the Croydon-Burlington 230 kV line conductor. The existing conductor is 1590 kcmil ACSR and will be replaced by 1622 kcmil ACSS/TW. (B3335)


**Note:** The upgrade overlaps with a deactivation study.

**Estimated Cost:** \$0.794 M

**Alternatives:** N/A

**Required In-Service:** 6/1/2026

**Projected In-Service:** 6/1/2023



**Process Stage:** Second Review

**Criteria:** Summer N-1 and Generator Deliverability

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP Summer case

**Proposal Window Exclusion:** Substation Equipment

**Problem Statement:**

The Juniata 500/230 kV transformer #2 is overloaded for line fault stuck breaker contingency.

Violations were posted as part of the 2021 Window 1: FG# N1-ST31 and GD-S429

**Existing Facility Rating:** 685SN/814SE, 842WN/911WE MVA

**Proposed Facility Rating:** 776SN/1010SE, 971WN/1040WE MVA

**Recommended Solution:**


Juniata: Replace the limiting 230kV T2 transformer leads, bay conductor and bus conductor with double bundle 1590 ACSR . Replace the limiting 1200A MODs on the Bus tie breaker with 3000A MODs. (B3664)

**Note:** If the S0945.1 (Rebuild Juniata 230 kV station) moves forward and construction is completed prior to 6/1/2026, the baseline project may not be needed and may be canceled.

**Estimated Cost:** \$0.684 M

**Alternatives:** N/A

**Required In-Service:** 6/1/2026





# Penelec Transmission Zone: Baseline

**Process Stage:** Second Review

**Criteria:** Summer Generator Deliverability

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP Summer case

**Proposal Window Exclusion:** Substation Equipment

**Problem Statement:**

East Towanda - Canyon 230 kV is overloaded for pre-contingency plus multiple contingencies.

Violations were posted as part of the 2021 Window 1: GD-S14, GD-S15, GD-S38

**Existing Facility Rating:** : 515SN/615SE, 619WN/703WE MVA

**Proposed Facility Rating:** 546SN/666SE, 619WN/790WE MVA.


**Recommended Solution :**

Replace several pieces of 1033.5 AAC substation conductor at East Towanda 230 kV. (B3665)

**Estimated Cost:** \$0.407 M

**Alternatives:** N/A

**Required In-Service:** 6/1/2026



**Process Stage:** Second Review

**Criteria:** Summer and Winter, N-1 and N-1-1 Voltage

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP Summer case

**Proposal Window Exclusion:** None

**Problem Statement:** Post-contingency high voltage violation in Penelec, Grover area. Potential voltage violation at the Grover and surrounding 230 kV stations for N-1, N-1-1 contingencies.

Violations were posted as part of the 2021 Window 1: (N1-SVM1, N1-SVM2, N2-SVM1, N2-SVM2, N2-SVM3, N2-SVM4, N2-SVM5, N2-SVM6, N2-SVM7, N1-WVM1, N1-WVM2, N1-WVM3, N1-WVM4, N2-WVM1, N2-WVM2, N2-WVM3, N2-WVM4, N2-WVM5, N2-WVM6, N2-WVM7, N2-WVM8, N2-WVM9)

**Existing Facility Rating:** N/A

**Recommended Solution :**

**Proposal ID 745 - Marshall 230 kV Substation:** Install dual reactors and expand existing ring bus . (B3666)


**Estimated Cost:** \$5.83 M

**Alternatives:**

**Proposal ID 634 - Grover 230 kV Substation:** Install dual reactors and convert the station to a ring bus. \$16.32

**Proposal ID 498 - Grover Substation:** Install two reactors and install line breakers. \$5.11 M

**Required In-Service:** 6/1/2026



**Process Stage:** Second Review

**Criteria:** Summer N-1-1 Voltage

**Assumption Reference:** 2026 RTEP assumption

**Model Used for Analysis:** 2026 RTEP Summer case

**Proposal Window Exclusion:** None

**Problem Statement:** Post-contingency voltage magnitude and voltage drop violation in Penelec, Mansfield area. Potential voltage violation at the Mansfield and surrounding 115 kV stations for N-1-1 contingencies.

Violations were posted as part of the 2021 Window 1: (N2-SVM48, N2-SVM49, N2-SVM50, N2-SVD19, N2-SVD20, N2-SVD21, N2-SVD22, N2-SVD23, N2-SVD24, N2-SVD25, N2-SVD26, N2-SVD27, N2-SVD28, N2-SVD29)

**Existing Facility Rating:** N/A


**Recommended Solution:**

**Proposal ID 101 - Pierce Brook Substation:** Install second 230/115 kV transformer. (B3667)

**Estimated Cost:** \$5.07 M

**Alternatives:** N/A

**Required In-Service:** 6/1/2026





# 2021 SAA Proposal Window to Support NJ OSW

Facilitator:  
Sue Glatz,  
Suzanne.Glatz@pjm.com

Secretary:  
Mike Zhang,  
Michael.Zhang@pjm.com

SME/Presenter:  
Aaron Berner,  
Aaron.Berner@pjm.com

## Reliability Analysis Update



### Member Hotline

(610) 666 – 8980

(866) 400 – 8980

custsvc@pjm.com

Version No.	Date	Description
1	10/28/2021	<ul style="list-style-type: none"> <li>Original slides posted</li> </ul>
2	10/29/2021	<ul style="list-style-type: none"> <li>Added slides 7, 8, 9, and 10, plus made a date correction on slide #6</li> </ul>
3	11/1/2021	<ul style="list-style-type: none"> <li>Corrected slide 13 header information</li> </ul>
4	11/4/2021	<ul style="list-style-type: none"> <li>Corrected transformer # on slide 8 (Lawrence 230/69 kV 220-4)</li> </ul>
5	11/9/2021	<ul style="list-style-type: none"> <li>Corrected FG#s on slide 58</li> </ul>
6	11/15/2021	<ul style="list-style-type: none"> <li>Corrected preliminary facility ratings on slide 42</li> </ul>
7	12/13/2021	<ul style="list-style-type: none"> <li>Slide #16, changed the 2nd “Required IS date” to “Projected IS date”</li> </ul>