



Energy Management System SCADA/AGC Upgrade / ICCP Configuration Required Changes

October 13, 2021

Jeff Tiemann, Sr. Manager, EMS
Technologies – Operations



Change Inter-Control Center Communications Protocol (ICCP) Configuration to the Transport Selector (TSEL) and Session Selector (SSEL) values to ensure uniqueness for multiple links to PJM

- 15 impacted members' ICCP contacts have been notified directly by the PJM EMS Networking Group
- The change involves updating the Manufacturing Message Specification (MMS) Stack configurations for ICCP Links
- The configuration change is compatible with the current PJM Siemens EMS system

PJM is targeting to have the ICCP configuration updates completed by ***December 15, 2021***, to validate prior to final cutover to the new PJM EMS

- Complete Association Information Exchange Form (AIEF) form exchange
- Test the Stage environment links prior to Production changes (if applicable)
- Coordinate and complete change
- Verify changes on all of applicable Energy Management System (EMS) servers and PJM servers
- Declare changes complete

Facilitator:
Foluso Afelumo, Foluso.Afelumo@pjm.com

Secretary:

Risa Holland, Risa.Holland@pjm.com

Presenter:

Jeff Tiemann, Jeffrey.Tiemann@pjm.com

ICCP Configuration Questions:

PJM EMS Networking

emsnet@pjm.com

Rapid Response Team – 610-666-8978



Member Hotline

(610) 666 – 8980

(866) 400 – 8980

custsvc@pjm.com