

Distributed Energy Resource Subcommittee Proposed changes to clarify participation rules

MRC

December 20, 2018

- Distributed Energy Resource have opportunity to:
 - reduce load as BtMG or as a DR resource and inject power (after reducing all load) with appropriate interconnection agreement
 - Operate as normal “front of the meter” generator with appropriate interconnection agreement
- Existing rules are not clear in the manuals
- “On-Site Generator” definition in DR section inconsistent in tariff sections and could be more clear

- Clarify existing rules for market participants
 - DER can participate as DR and inject power (with proper interconnection agreement) today
 - Load reductions modelled as DR resource and subject to existing DR rules
 - Injections modelled as a generator and subject to existing generation rules
- Clarify existing On-Site Generator definition (in definition section), eliminate On-Site Generator definition in Emergency/Pre-Emergency section, use On-Site Generator term consistently (not On Site Generator or On Site Generation).


DERS work continues, this may not be end state

- OA/OATT - DEFINITIONS, 3.3A.7, 8.2
- Manual 11 - 10.2
- Manual 14D - 4.2

Change from first read based on DERS comment for clarification

- Generators that will also participate as PJM demand response resources and that have PJM approved interconnection rights to inject power must provide Instantaneous Net (+/-) MW and MVAR at the point of interconnection and Instantaneous Net (+/-) MW and MVAR ~~for each unit~~, measured on the low-side of generator step-up transformer at a point where it does not include associated load served by the generator.


DER Use Case Example: Demand Response and Generation at the same site



- Generator = 10 MW
- MFO = 10 MW
 - Max Facility Output
- Peak Load = 5 MW
- Generator CIR = 4 MW
 - Capacity Interconnection Rights


Generator went through New Services Queue to obtain either ISA or WMPA

Scenario 1: Generator used to reduce all load for the wholesale market as DR



May be eligible for 5 MW of energy payment for DR resource load reduction

Scenario 2: Generator used to reduce load and inject




Current POI meter reads +6 MW

Paid for 6 MW as Gen resource, not eligible for DR revenue if operated for export (considered part of "normal operations")

Scenario 3: No load and Generator at full output

GEN OUTPUT 10MW

Load = 0



Current POI meter reads +10 MW

Paid for 10 MW as Gen resource, No load at the facility