



Sub Regional RTEP Committee Mid-Atlantic - PSEG Solution Meeting

November 28, 2018

Need Number: PSEG-2018-0004

Need Presented: 10/29/2018

Meeting Date: 11/28/2018

Process Stage: Solution Meeting

Project Drivers:


- Operational Flexibility and Efficiency
- Equipment Material Condition, Performance and Risk

Problem Statement:

- Lawnside is a straight bus fed by four 69kV lines that serves roughly 24,000 customers and 113 MVA of load.
 - A stuck breaker condition on any of the 69kV bus section breakers causes the loss of three 69kV lines and two transformers, leaving the station with only a single 69kV supply. This results in an unacceptable voltage drop of roughly 7%.
- Poor circuit performance on the Lawnside-Maple Shade 69kV circuit.
 - Over the past five years, the Lawnside-Maple Shade 69kV circuit has experienced 11 extended outages and 13 momentary outages, with total duration of over 113 hours.

Specific Assumption References:

- [PSE&G 2018 Annual Assumptions](#)




Need Number: PSEG-2018-0004

Proposed Solution:

- Lawnside 69kV Reconfiguration
 - Purchase neighboring property to accommodate construction
 - Reconfigure bus to a 69kV breaker-and-a-half bus.
 - **Estimated Cost:** \$46M
 - **Projected In-Service Date:** 12/2022
- Poor circuit performance on the Lawnside-Maple Shade 69kV circuit has been referred for further evaluation prior to moving forward with this portion of the recommended solution.

TO Alternatives Considered:

- Alternative 1
 - Install one 30 MVAR SVC or STATCOM.
 - Not feasible. SVC alone would not address the stuck breaker condition need. Would require full bus reconfiguration in addition to the two capacitor banks



Need Number: PSEG-2018-0005

Need Presented: 10/29/2018

Meeting Date: 11/28/2018

Process Stage: Solution Meeting

Project Drivers:


- Operational Flexibility and Efficiency
- Equipment Material Condition, Performance and Risk

Problem Statement:

- Poor station reliability at Mount Rose.
 - Mount Rose experienced station shutdowns due to loss of all 69kV supply in 2016 and 2018.
 - Over the past decade, the three 69kV supply circuits at Mount Rose have experienced 21 extended outages and 9 momentary outages, with total duration of over 207 hours.
- Mount Rose serves roughly 11,000 customers and 60 MVA of load.
- Mount Rose is a straight bus fed by three 69kV lines.
- Several contingencies that would result in unacceptable voltage drops:
 - An N-1-1 condition on 69kV supplies in the network leaves Mount Rose and several customer substations in the area with only long distance, daisy-chained paths to 230kV sources. The voltage drops by roughly 7%.
 - A stuck breaker condition on the capacitor bank breaker causes the loss of two 69kV lines and the capacitor bank, leaving the station with only a single 69kV supply. The voltage drops by roughly 6%.
 - A stuck breaker condition on the bus section breaker results in the loss of the entire station.

Specific Assumption References:

- [PSE&G 2018 Annual Assumptions](#)




Need Number: PSEG-2018-0005

Proposed Solution:

- Mount Rose 69kV Reconfiguration
 - Purchase neighboring property to accommodate construction
 - Reconfigure bus to a 69kV ring bus.
 - Construct a new 69kV circuit to Hopewell Switching Station.
 - **Estimated Cost:** \$66M
 - **Projected In-Service Date:** 06/2022

TO Alternatives Considered:

- Alternative 1
 - Purchase property at a nearby alternate location to accommodate construction of a new station.
 - At alternate location, construct a new 69kV station.
 - Install 69kV ring bus with two (2) 69/13kV transformers.
 - Reconfigure existing 69kV circuits at Mount Rose to new station.
 - Construct a new 69kV circuit to Hopewell Switching Station
 - Eliminate existing Mount Rose station.
 - **Estimated Cost:** \$81M





Sub Regional RTEP Committee Mid-Atlantic - PSEG Need Meeting

November 28, 2018



PSEG Transmission Zone

Need Number: PSEG-2018-0006

Meeting Date: 11/28/2018

Process Stage: Needs Meeting

Project Drivers:


- Customer Service

Problem Statement:

- Stations in the New Brunswick area are at or near capacity. There is a need for additional capacity in the area.
 - Adams serves roughly 22,000 customers and 83 MVA of load.
 - Bennetts Lane serves roughly 21,000 customers and 83 MVA of load.
 - Brunswick serves roughly 10,000 customers and 46 MVA of load.
 - Station capacity for each station is 60 MVA, excluding the value of inter-station ties.

Specific Assumption References:

- [PSE&G 2018 Annual Assumptions](#)



Need Number: PSEG-2018-0007

Meeting Date: 11/28/2018

Process Stage: Needs Meeting

Project Drivers:


- Customer Service
- Equipment Material Condition, Performance and Risk

Problem Statement:

- Stations around Texas Ave are at or near capacity. There is a need for additional capacity in the area.
 - Lawrence serves roughly 26,000 customers and 121 MVA of load.
- Texas Ave is a unit substation supplied by two 26kV circuits with increasing performance problems.
 - Over the past decade, the two 26kV supply circuits at Texas have experienced 10 extended outages and 32 momentary outages, with total duration of over 82 hours.
- Station equipment at Texas Ave has been in service for over 60 years. This equipment has been identified as being in poor condition and needs to be addressed.
 - Texas Ave serves roughly 1,000 customers and 5 MVA of load.

Specific Assumption References:

- [PSE&G 2018 Annual Assumptions](#)





Revision History

11/16/2018 – V1 – Original version posted to pjm.com