



# Sub Regional RTEP Committee PJM Mid-Atlantic First Energy MAAC

January 25, 2019

# Solutions

## Supplemental Reliability Upgrades



Need Number: ME-2018-019

Need Presented: 11/28/2018

Meeting Date: 1/25/2019

Process Stage: Solution Meeting

### Project Driver(s):

*Equipment Material Condition, Performance and Risk*


### Specific Assumption Reference(s)

- Substation Condition Rebuild/Replacement

### Problem Statement

Jackson #5 230/115 kV:

- Transformer is 48 years old
- Dissolved gas in oil
- History of oil leaks, compromising oil integrity



**Need Number:** ME-2018-019

**Proposed Solution:**

*Jackson #5 230/115 kV transformer replacement*

Replace the 230/115 kV 90/120/150 MVA transformer and associated equipment with new 230/115 kV 180/240/300 MVA transformer

**Transformer Ratings:**

Jackson #5 230/115 kV Transformer


- Before Proposed Solution: 193 MVA SN / 244 MVA SE
- After Proposed Solution (anticipated): 361 MVA SN / 387 MVA SE

**Alternatives Considered:**

Maintain existing condition at elevated risk of failure

**Estimated Project Cost:** \$4.9 M

**Projected IS Date:** 12/31/2020



| Legend |  |
|--------|--|
| 500 kV |  |
| 230 kV |  |
| 138 kV |  |
| 115 kV |  |
| 69 kV  |  |
| 46 kV  |  |
| New    |  |

Need Number: ME-2018-020

Need Presented: 11/28/2018

Meeting Date: 1/25/2019

Process Stage: Solution Meeting

## Project Driver(s):

*Equipment Material Condition, Performance and Risk*


## Specific Assumption Reference(s)

- Substation Condition Rebuild/Replacement

## Problem Statement

North Hershey #1 230-69 kV:

- Transformer is over 40 years old
- Critical role in operation of 69 kV
- Transformer leaking





**Need Number:** ME-2018-020

**Proposed Solution:**

*North Hershey #1 230-69 kV transformer replacement and 230 kV ring bus*

- Replace the 230-69 kV 60/80/100 MVA transformer and associated equipment with new 230-69 kV 100/134/168 MVA transformer
- Expand the North Hershey 230 kV bus into a three breaker ring bus.

**Transformer Ratings:**

North Hershey #1 230-69 kV transformer

- Before Proposed: 123 MVA SN / 137 MVA SE
- After Proposed Solution (anticipated): 211 MVA SN / 232 MVA SE


**Alternatives Considered:**

Maintain existing condition at elevated risk of failure

**Estimated Project Cost:** \$9.1 M

**Projected IS Date:** 12/31/2021

| Legend |  |
|--------|--|
| 500 kV |  |
| 230 kV |  |
| 138 kV |  |
| 115 kV |  |
| 69 kV  |  |
| 46 kV  |  |
| New    |  |



Need Number: ME-2018-021

Need Presented: 11/28/2018

Meeting Date: 1/25/2019

Process Stage: Solution Meeting

Project Driver(s):


*Customer Service (Reliability)*

**Specific Assumption Reference(s)**

Customer request will be evaluated per FirstEnergy's "Requirements for Transmission Connected Facilities" document and "Transmission Planning Criteria" document.

**Problem Statement**

- Customer requested transmission service in the Stroudsburg, PA area due to multiple outages over past several years.
- Limited outage restoration options in the area.
- **The area north of Shawnee substation has no transmission system**
- **Customers in this area are served by three 34.5 kV circuits from Shawnee or from Walker substation which is radial 69 kV.**
- **6000 customers directly served by the 34.5 kV circuits**
- **7600 customers fed from substations sourced by the 34.5 kV system**
- **Territory is a narrow corridor bounded by the Delaware river to the east**





**Need Number:** ME-2018-021

**Proposed Solution:**

*Construct a new 69 kV transmission line from Shawnee Substation to Walker Substation (approximately 31.1 miles)*

**Shawnee Substation**

- Expand 230 kV bus into a six breaker ring bus
- Install a new 100/134/168 MVA 230-69 kV transformer and associated equipment

**Birchwood Lakes Substation**

- Provide new 69 kV delivery point
- Install a new 69 kV 9.6 MVAR capacitor.

**Bushkill Falls Substation**

- Provide new 69 kV delivery point
- Install a new 69 kV 9.6 MVAR capacitor.

**Walker Substation**


- Expand 69 kV bus into a three breaker ring bus.

**Alternatives Considered:**

- New 115 kV transmission line from Shawnee to a new 230/115 kV substation
- New 230 kV transmission line from Shawnee to Blooming Grove

**Estimated Project Cost:** \$60 M

**Projected IS Date:** 12/31/2023



| Legend |  |
|--------|--|
| 500 kV |  |
| 230 kV |  |
| 138 kV |  |
| 115 kV |  |
| 69 kV  |  |
| 46 kV  |  |
| New    |  |



Questions?





# Revision History

1/15/2019 – V1 – Original version posted to [pjm.com](http://pjm.com)

1/24/2019 – V2 - All Need slides #9 - #30 removed