



Responses to RASTF Data Analysis requests


Patricio Rocha Garrido
Resource Adequacy Planning
RASTF
January 18, 2023




Estimates of “Headroom” under an Annual RPM Construct

- Headroom could be calculated based on Monthly Reserve Targets (MRTs).
 - Headroom refers to the outage MWs that PJM could potentially accommodate based on a reliability criteria
 - MRTs are only calculated for illustrative purposes for this presentation
- MRTs are calculated using a methodology similar to the Winter Weekly Reserve Target methodology but applied to each month of the year
- Two LOLE threshold levels were used to estimate the “Monthly Reserve Targets”
 - 0.001 days/year (currently used in WWRT procedure)
 - 0.01 days/year

- Procedure
 - Step 1: Set up an IRM case with total LOLE = 0.1 days/year.
 - Step 2: In addition to the required planned outage schedule, simulate additional planned outages during each week of the year **until the weekly LOLE is the threshold level.**
 - If the weekly LOLE is already greater than the threshold level, do not model any planned outages in that week.
 - Step 3: Calculate the available reserves in each of the weeks as a percentage of the corresponding monthly peak.
 - Step 4: The MRT for each month is the highest weekly reserve percentage (rounded up to the next integer value).



2022/23 DY MRT values using 0.01 days/year threshold




- An estimate of the Headroom expected to be used can be derived by using
 - Planned outage requirement data for delivery year 2022/23 from the 2022 RRS
 - Planned outage schedule derived by levelizing reserves
- The “expected used headroom” is derived for
 - An annual construct using actual reserves and 1-in-10 reserves
 - A 2-season seasonal construct using 1-in-10 reserves
 - A 3-season seasonal construct using 1-in-10 reserves

- Planned outage requirement, forced outage rates taken from the 2022 RRS based on actual fleet for delivery year 2022/23
- Load uncertainty taken from the 2022 RRS for delivery year 2022/23
- RTO-wide planned outage requirement and schedule is kept constant in the 1- in-10 reserve scenarios and different seasonal design scenarios




Expected Used Headroom – Annual Construct – Actual Reserves – 0.01 days/year threshold






Expected Used Headroom – Annual Construct – Actual Reserves – 0.001 days/year threshold






Expected Used Headroom – Annual Construct – 1in10 Reserves – 0.01 days/year threshold






Expected Used Headroom – Annual Construct – 1in10 Reserves – 0.001 days/year threshold






Expected Used Headroom – 2-Season Construct – 50/50 Summer/Winter LOLE Allocation - 1in10 Reserves – 0.001 days/year threshold






Expected Used Headroom – 2-Season Construct – 90/10 Summer/Winter LOLE Allocation - 1in10 Reserves – 0.001 days/year threshold





Expected Used Headroom – 3-Season Construct – 33/33/33 Summer/Winter/Shoulder LOLE Allocation - 1in10 Reserves – 0.001 days/year threshold



SME/Presenter:

Patricio Rocha-Garrido

Patricio.Rocha-Garrido@pjm.com

Responses to RASTF Data Analysis requests



Member Hotline

(610) 666 – 8980

(866) 400 – 8980

custsvc@pjm.com

**PROTECT THE
POWER GRID
THINK BEFORE
YOU CLICK!**



Be alert to
malicious
phishing emails.

Report suspicious email activity to PJM.
(610) 666-2244 / it_ops_ctr_shift@pjm.com

